

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
CER 005	Faculty rm 121 SINK	10/8/2024 08:25	1/22/2025 16:15	70332841006	Lead	3.2	5	ug/L
CER 006	HALLWAY DRINKING FOUNTAIN	10/8/2024 08:23	1/22/2025 16:11	70332841004	Lead	<1.0	5	ug/L
CER 007	HALLWAY BOTTLE FILLER	10/8/2024 08:24	1/22/2025 16:13	70332841005	Lead	<1.0	5	ug/L
CER 011	CLASS ROOM 109 SINK	10/8/2024 08:30	1/22/2025 16:30	70332841012	Lead	2.5	5	ug/L
CER 012	HALLWAY DRINKING FOUNTAIN	10/8/2024 08:28	1/22/2025 16:21	70332841010	Lead	<1.0	5	ug/L
CER 013	HW by CR 109 BF	10/8/2024 08:29	1/22/2025 16:26	70332841011	Lead	<1.0	5	ug/L
CER 015	CLASS ROOM 113 SINK	10/8/2024 08:32	1/22/2025 16:39	70332841014	Lead	<1.0	5	ug/L
CER 017	CLASS ROOM 115 SINK	10/8/2024 08:36	1/22/2025 16:45	70332841016	Lead	2.2	5	ug/L
CER 020	CLASS ROOM 117 SINK	10/8/2024 08:37	1/22/2025 16:50	70332841019	Lead	1.4	5	ug/L
CER 021	CLASS ROOM 112 SINK	10/8/2024 08:36	1/22/2025 16:47	70332841017	Lead	3.8	5	ug/L
CER 024	CLASS ROOM 110 SINK	10/8/2024 08:36	1/22/2025 16:48	70332841018	Lead	<1.0	5	ug/L
CER 026	CLASS ROOM 110 SINK	10/8/2024 08:33	1/22/2025 16:44	70332841015	Lead	6.1	5	ug/L
CER 027	CLASS ROOM 108 SINK	10/8/2024 08:30	1/22/2025 16:35	70332841013	Lead	1.3	5	ug/L
CER 030	CLASS ROOM 106 SINK	10/8/2024 08:26	1/22/2025 16:18	70332841008	Lead	11.0	5	ug/L
CER 031	NURSE OFFICE 104 SINK	10/8/2024 08:25	1/22/2025 16:16	70332841007	Lead	1.7	5	ug/L
CER 032	NURSE EXAM RM 104 SINK	10/8/2024 08:27	1/22/2025 16:19	70332841009	Lead	2.3	5	ug/L
CER 035A	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:55	1/22/2025 17:41	70332841041	Lead	<1.0	5	ug/L
CER 035B	HALLWAY BOTTLE FILLER	10/10/2024 06:55	1/22/2025 17:43	70332841042	Lead	<1.0	5	ug/L
CER 036	CLASS ROOM 180 SINK	10/10/2024 06:58	1/22/2025 17:44	70332841043	Lead	12.9	5	ug/L
CER 037	CLASS ROOM 182 SINK	10/10/2024 06:59	1/22/2025 17:46	70332841044	Lead	9.1	5	ug/L
CER 038	CLASS ROOM 184 SINK	10/10/2024 07:00	1/22/2025 17:47	70332841045	Lead	15.7	5	ug/L
CER 039	CLASS ROOM 183 SINK	10/10/2024 07:02	1/22/2025 17:49	70332841046	Lead	6.4	5	ug/L
CER 040	CLASS ROOM 181 SINK	10/10/2024 07:04	1/22/2025 17:50	70332841047	Lead	5.9	5	ug/L
CER 046	Art Rm storage SINK	10/10/2024 06:33	1/22/2025 18:06	70332841021	Lead	97.0	5	ug/L
CER 047	comp rm 156 SINK	10/10/2024 06:37	1/22/2025 16:55	70332841023	Lead	7.4	5	ug/L
CER 049	CLASS ROOM 158 SINK	10/10/2024 06:38	1/22/2025 16:56	70332841024	Lead	3.5	5	ug/L
CER 055	CLASS ROOM 166 SINK	10/10/2024 06:42	1/22/2025 17:09	70332841030	Lead	7.5	5	ug/L
CER 056	CLASS ROOM 168 SINK	10/10/2024 06:43	1/22/2025 17:10	70332841031	Lead	12.9	5	ug/L
CER 057	CLASS ROOM 169 SINK	10/10/2024 06:44	1/22/2025 17:12	70332841032	Lead	2.9	5	ug/L
CER 058	CLASS ROOM 167 SINK	10/10/2024 06:44	1/22/2025 17:17	70332841033	Lead	3.3	5	ug/L
CER 059	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:41	1/22/2025 17:06	70332841028	Lead	<1.0	5	ug/L

CER 060	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:40	1/22/2025 17:02	70332841026	Lead	<1.0	5	ug/L
CER 061	HALLWAY BOTTLE FILLER	10/10/2024 06:40	1/22/2025 17:04	70332841027	Lead	<1.0	5	ug/L
CER 062	CLASS ROOM 165 SINK	10/10/2024 06:41	1/22/2025 17:07	70332841029	Lead	2.4	5	ug/L
CER 063	CLASS ROOM 157 SINK	10/10/2024 06:39	1/22/2025 16:58	70332841025	Lead	6.7	5	ug/L
CER 065	CLASS ROOM 155 SINK	10/10/2024 06:34	1/22/2025 16:53	70332841022	Lead	8.2	5	ug/L
CER 068	KITCHEN SINK	10/8/2024 08:20	1/22/2025 16:10	70332841003	Lead	<1.0	5	ug/L
CER 069	KITCHEN SINK	10/8/2024 08:19	1/22/2025 16:08	70332841002	Lead	2.0	5	ug/L
CER 071	KITCHEN SINK	10/8/2024 08:15	1/22/2025 16:07	70332841001	Lead	3.8	5	ug/L
CER 075	Music office Rm 134 SINK	10/10/2024 07:08	1/22/2025 17:52	70332841048	Lead	18.2	5	ug/L
CER 081	CLASS ROOM 212 SINK	10/10/2024 06:48	1/22/2025 17:24	70332841034	Lead	9.0	5	ug/L
CER 082	CLASS ROOM 214 SINK	10/10/2024 06:50	1/22/2025 17:32	70332841037	Lead	11.2	5	ug/L
CER 083	CLASS ROOM 216 SINK	10/10/2024 06:50	1/22/2025 17:33	70332841038	Lead	16.1	5	ug/L
CER 084	CLASS ROOM 217 SINK	10/10/2024 06:51	1/22/2025 17:35	70332841039	Lead	15.8	5	ug/L
CER 085	CLASS ROOM 215	10/10/2024 06:51	1/22/2025 17:39	70332841040	Lead	4.9	5	ug/L
CER 086	HALLWAY BOTTLE FILLER	10/10/2024 06:49	1/22/2025 17:28	70332841035	Lead	<1.0	5	ug/L
CER 087	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:49	1/22/2025 17:30	70332841036	Lead	<1.0	5	ug/L
CER 088	SPIGOT OFF Main	10/8/2024 08:45	1/22/2025 16:52	70332841020	Lead	1.7	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb



January 24, 2025

Pete Colucci  
CiTi BOCES Oswego City School District  
2 Buccaneer Blvd  
Oswego, NY 13126

RE: Project: CHARLES E RILEY ELEMENTARY  
Pace Project No.: 70332841

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen  
michelle.cohen@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District  
CiTi BOCES Safety and, CiTi BOCES Oswego City School  
District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 071	Lab ID: 70332841001	Collected: 10/08/24 08:15	Received: 01/15/25 06:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>3.8</b>	ug/L	1.0	1		01/22/25 16:07	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 069</b>								
<b>Lab ID: 70332841002</b>								
Collected: 10/08/24 08:19								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.0</b>	ug/L	1.0	1		01/22/25 16:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 068		Lab ID: 70332841003	Collected: 10/08/24 08:20	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 16:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 006		Lab ID: 70332841004	Collected: 10/08/24 08:23	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 16:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 007</b>								
<b>Lab ID: 70332841005</b>								
Collected: 10/08/24 08:24 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/22/25 16:13	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 005</b>								
<b>Lab ID: 70332841006</b>								
Collected: 10/08/24 08:25 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>3.2</b>	ug/L	1.0	1		01/22/25 16:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 031</b>								
<b>Lab ID: 70332841007</b>								
Collected: 10/08/24 08:25 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		01/22/25 16:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 030</b>								
<b>Lab ID: 70332841008</b>								
Collected: 10/08/24 08:26								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	11.0	ug/L	1.0	1		01/22/25 16:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 032</b>								
<b>Lab ID: 70332841009</b>								
Collected: 10/08/24 08:27								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.3</b>	ug/L	1.0	1		01/22/25 16:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 012</b>								
<b>Lab ID: 70332841010</b>								
Collected: 10/08/24 08:28								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 16:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 013</b>								
<b>Lab ID: 70332841011</b>								
Collected: 10/08/24 08:29								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 16:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 011</b>								
<b>Lab ID: 70332841012</b>								
Collected: 10/08/24 08:30								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.5	ug/L	1.0	1		01/22/25 16:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 027</b>								
<b>Lab ID: 70332841013</b>								
Collected: 10/08/24 08:30 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.3	ug/L	1.0	1		01/22/25 16:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 015</b>								
<b>Lab ID: 70332841014</b>								
Collected: 10/08/24 08:32 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/22/25 16:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 026</b>								
<b>Lab ID: 70332841015</b>								
Collected: 10/08/24 08:33								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.1	ug/L	1.0	1		01/22/25 16:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 017</b>								
<b>Lab ID: 70332841016</b>								
Collected: 10/08/24 08:36								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.2	ug/L	1.0	1		01/22/25 16:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 021	Lab ID: 70332841017	Collected: 10/08/24 08:36	Received: 01/15/25 06:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<b>3.8</b>	ug/L	1.0	1		01/22/25 16:47	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 024</b>								
<b>Lab ID: 70332841018</b>								
Collected: 10/08/24 08:36								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 16:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 020</b>								
<b>Lab ID: 70332841019</b>								
Collected: 10/08/24 08:37								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.4	ug/L	1.0	1		01/22/25 16:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 088</b>								
<b>Lab ID: 70332841020</b>								
Collected: 10/08/24 08:45 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.7	ug/L	1.0	1		01/22/25 16:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 046		Lab ID: 70332841021	Collected: 10/10/24 06:33	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>97.0</b>	ug/L	1.0	1	01/22/25 07:20	01/22/25 18:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 065</b>								
<b>Lab ID: 70332841022</b>								
Collected: 10/10/24 06:34								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>8.2</b>	ug/L	1.0	1		01/22/25 16:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 047		Lab ID: 70332841023	Collected: 10/10/24 06:37	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		01/22/25 16:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 049		Lab ID: 70332841024	Collected: 10/10/24 06:38	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.5</b>	ug/L	1.0	1		01/22/25 16:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 063		Lab ID: 70332841025	Collected: 10/10/24 06:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.7</b>	ug/L	1.0	1		01/22/25 16:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 060</b>								
<b>Lab ID: 70332841026</b>								
Collected: 10/10/24 06:40								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 17:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 061</b>								
<b>Lab ID: 70332841027</b>								
Collected: 10/10/24 06:40 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/22/25 17:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 059		Lab ID: 70332841028	Collected: 10/10/24 06:41	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 17:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 062		Lab ID: 70332841029	Collected: 10/10/24 06:41	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		01/22/25 17:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 055</b>								
<b>Lab ID: 70332841030</b>								
Collected: 10/10/24 06:42								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	7.5	ug/L	1.0	1		01/22/25 17:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 056</b>								
<b>Lab ID: 70332841031</b>								
Collected: 10/10/24 06:43								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>12.9</b>	ug/L	1.0	1		01/22/25 17:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 057</b>								
<b>Lab ID: 70332841032</b>								
Collected: 10/10/24 06:44								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.9</b>	ug/L	1.0	1		01/22/25 17:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 058</b>								
<b>Lab ID: 70332841033</b>								
Collected: 10/10/24 06:44								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.3	ug/L	1.0	1		01/22/25 17:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 081</b>								
<b>Lab ID: 70332841034</b>								
Collected: 10/10/24 06:48								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>9.0</b>	ug/L	1.0	1		01/22/25 17:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 086</b>								
<b>Lab ID: 70332841035</b>								
Collected: 10/10/24 06:49								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 17:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 087</b>								
<b>Lab ID: 70332841036</b>								
Collected: 10/10/24 06:49								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 17:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 082		Lab ID: 70332841037	Collected: 10/10/24 06:50	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>11.2</b>	ug/L	1.0	1		01/22/25 17:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 083</b>								
<b>Lab ID: 70332841038</b>								
Collected: 10/10/24 06:50								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	16.1	ug/L	1.0	1		01/22/25 17:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 084</b>								
<b>Lab ID: 70332841039</b>								
Collected: 10/10/24 06:51								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	15.8	ug/L	1.0	1		01/22/25 17:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 085</b>								
<b>Lab ID: 70332841040</b>								
Collected: 10/10/24 06:51 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>4.9</b>	ug/L	1.0	1		01/22/25 17:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 035A		Lab ID: 70332841041	Collected: 10/10/24 06:55	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 17:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 035B</b>								
<b>Lab ID: 70332841042</b>								
Collected: 10/10/24 06:55								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 17:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 036</b>								
<b>Lab ID: 70332841043</b>								
Collected: 10/10/24 06:58								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>12.9</b>	ug/L	1.0	1		01/22/25 17:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 037</b>								
<b>Lab ID: 70332841044</b>								
Collected: 10/10/24 06:59								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	9.1	ug/L	1.0	1		01/22/25 17:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Sample: CER 038		Lab ID: 70332841045	Collected: 10/10/24 07:00	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>15.7</b>	ug/L	1.0	1		01/22/25 17:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 039</b>								
<b>Lab ID: 70332841046</b>								
Collected: 10/10/24 07:02								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.4	ug/L	1.0	1		01/22/25 17:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 040</b>								
<b>Lab ID: 70332841047</b>								
Collected: 10/10/24 07:04								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>5.9</b>	ug/L	1.0	1		01/22/25 17:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: CER 075</b>								
<b>Lab ID: 70332841048</b>								
Collected: 10/10/24 07:08								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>18.2</b>	ug/L	1.0	1		01/22/25 17:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

QC Batch:	381128	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332841001, 70332841002, 70332841003, 70332841004, 70332841005, 70332841006, 70332841007, 70332841008, 70332841009, 70332841010, 70332841011		

METHOD BLANK:	2000312	Matrix:	Water
Associated Lab Samples:	70332841001, 70332841002, 70332841003, 70332841004, 70332841005, 70332841006, 70332841007, 70332841008, 70332841009, 70332841010, 70332841011		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 15:37	

LABORATORY CONTROL SAMPLE:	2000313					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE:	2000315						
Parameter	Units	70332839023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.1	100	70-130	

MATRIX SPIKE SAMPLE:	2000317						
Parameter	Units	70332839024 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.2	94	70-130	

SAMPLE DUPLICATE:	2000314					
Parameter	Units	70332839023 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	2000316					
Parameter	Units	70332839024 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

QC Batch: 381152

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70332841012, 70332841013, 70332841014, 70332841015, 70332841016, 70332841017, 70332841018, 70332841019, 70332841020, 70332841022, 70332841023, 70332841024, 70332841025, 70332841026, 70332841027, 70332841028, 70332841029, 70332841030, 70332841031, 70332841032

METHOD BLANK: 2000488

Matrix: Water

Associated Lab Samples: 70332841012, 70332841013, 70332841014, 70332841015, 70332841016, 70332841017, 70332841018, 70332841019, 70332841020, 70332841022, 70332841023, 70332841024, 70332841025, 70332841026, 70332841027, 70332841028, 70332841029, 70332841030, 70332841031, 70332841032

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 16:27	

LABORATORY CONTROL SAMPLE: 2000489

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.6	101	85-115	

MATRIX SPIKE SAMPLE: 2000491

Parameter	Units	70332841012 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.5	100	101	98	70-130	

MATRIX SPIKE SAMPLE: 2000493

Parameter	Units	70332841013 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.3	100	97.5	96	70-130	

SAMPLE DUPLICATE: 2000490

Parameter	Units	70332841012 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.5	2.5	0	

SAMPLE DUPLICATE: 2000492

Parameter	Units	70332841013 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.3	1.3	4	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

QC Batch:	381153	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332841033, 70332841034, 70332841035, 70332841036, 70332841037, 70332841038, 70332841039, 70332841040, 70332841041, 70332841042, 70332841043, 70332841044, 70332841045, 70332841046, 70332841047, 70332841048		

METHOD BLANK:	2000494	Matrix:	Water
Associated Lab Samples:	70332841033, 70332841034, 70332841035, 70332841036, 70332841037, 70332841038, 70332841039, 70332841040, 70332841041, 70332841042, 70332841043, 70332841044, 70332841045, 70332841046, 70332841047, 70332841048		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 17:14	

LABORATORY CONTROL SAMPLE:	2000495					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	2000497						
Parameter	Units	70332841033 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	3.3	100	98.9	96	70-130	

MATRIX SPIKE SAMPLE:	2000499						
Parameter	Units	70332841034 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	9.0	100	109	100	70-130	

SAMPLE DUPLICATE:	2000496					
Parameter	Units	70332841033 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.3	3.3	0		

SAMPLE DUPLICATE:	2000498					
Parameter	Units	70332841034 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	9.0	8.5	5		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

QC Batch: 381079	Analysis Method: EPA 200.8
QC Batch Method: EPA 200.8	Analysis Description: 200.8 MET Drinking Water
	Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70332841021

METHOD BLANK: 2000018 Matrix: Water

Associated Lab Samples: 70332841021

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 17:58	

Parameter	Units	2000019		2000020		% Rec Limits	RPD	Max RPD	Qualifiers
		Spike Conc.	LCS Result	LCSD Result	LCS % Rec				
Lead	ug/L	50	51.4	50.7	103	101	85-115	1	20

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





## QUALIFIERS

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CHARLES E RILEY ELEMENTARY

Pace Project No.: 70332841

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332841021	CER 046	EPA 200.8	381079	EPA 200.8	381091
70332841001	CER 071	EPA 200.8	381128		
70332841002	CER 069	EPA 200.8	381128		
70332841003	CER 068	EPA 200.8	381128		
70332841004	CER 006	EPA 200.8	381128		
70332841005	CER 007	EPA 200.8	381128		
70332841006	CER 005	EPA 200.8	381128		
70332841007	CER 031	EPA 200.8	381128		
70332841008	CER 030	EPA 200.8	381128		
70332841009	CER 032	EPA 200.8	381128		
70332841010	CER 012	EPA 200.8	381128		
70332841011	CER 013	EPA 200.8	381128		
70332841012	CER 011	EPA 200.8	381152		
70332841013	CER 027	EPA 200.8	381152		
70332841014	CER 015	EPA 200.8	381152		
70332841015	CER 026	EPA 200.8	381152		
70332841016	CER 017	EPA 200.8	381152		
70332841017	CER 021	EPA 200.8	381152		
70332841018	CER 024	EPA 200.8	381152		
70332841019	CER 020	EPA 200.8	381152		
70332841020	CER 088	EPA 200.8	381152		
70332841022	CER 065	EPA 200.8	381152		
70332841023	CER 047	EPA 200.8	381152		
70332841024	CER 049	EPA 200.8	381152		
70332841025	CER 063	EPA 200.8	381152		
70332841026	CER 060	EPA 200.8	381152		
70332841027	CER 061	EPA 200.8	381152		
70332841028	CER 059	EPA 200.8	381152		
70332841029	CER 062	EPA 200.8	381152		
70332841030	CER 055	EPA 200.8	381152		
70332841031	CER 056	EPA 200.8	381152		
70332841032	CER 057	EPA 200.8	381152		
70332841033	CER 058	EPA 200.8	381153		
70332841034	CER 081	EPA 200.8	381153		
70332841035	CER 086	EPA 200.8	381153		
70332841036	CER 087	EPA 200.8	381153		
70332841037	CER 082	EPA 200.8	381153		
70332841038	CER 083	EPA 200.8	381153		
70332841039	CER 084	EPA 200.8	381153		
70332841040	CER 085	EPA 200.8	381153		
70332841041	CER 035A	EPA 200.8	381153		
70332841042	CER 035B	EPA 200.8	381153		
70332841043	CER 036	EPA 200.8	381153		
70332841044	CER 037	EPA 200.8	381153		
70332841045	CER 038	EPA 200.8	381153		
70332841046	CER 039	EPA 200.8	381153		
70332841047	CER 040	EPA 200.8	381153		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CHARLES E RILEY ELEMENTARY  
Pace Project No.: 70332841

---

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332841048	CER 075	EPA 200.8	381153		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.









**WO#: 70332841**

Client Name: Oswego City CS Project #

PM: MC1 Due Date: 01/24/25

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pack  Other

CLIENT: **OswegoCityCS**

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No  
 Packing Material:  Bubble Wrap  Bubble Bags  Ziploc  None  Other Type of Ice: Wet Blue None

Thermometer Used: T211 Correction Factor: +0.0  Samples on ice, cooling process has begun  
 Cooler Temperature (°C): 16.1° Cooler Temperature Corrected (°C): 16.1° Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6.0°C

USDA Regulated Soil (  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 1/15/25 AEB

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: <u>SL</u> <u>WT</u> OIL OTHER	

Date and Initials of person checking preservation: 1/15/25 AEB

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>213624</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide)	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.