

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
KPS-001	CLASSROOM 006 SINK	10/10/2024 05:44	1/22/2025 15:22	70332839014	Lead	<1.0	5	ug/L
KPS-003	CLASSROOM 006 SINK	10/10/2024 05:47	1/22/2025 15:25	70332839016	Lead	10.7	5	ug/L
KPS-005	CLASSROOM 001 SINK	10/10/2024 05:45	1/22/2025 15:23	70332839015	Lead	<1.0	5	ug/L
KPS-006	CLASSROOM 003 SINK	10/10/2024 05:42	1/22/2025 15:20	70332839013	Lead	<1.0	5	ug/L
KPS-007	CLASSROOM 005 SINK	10/10/2024 05:41	1/22/2025 15:18	70332839012	Lead	8.2	5	ug/L
KPS-008	CLASSROOM 007 SINK	10/10/2024 05:39	1/22/2025 15:17	70332839011	Lead	7.8	5	ug/L
KPS-012	HALLWAY BOTTLE FILLER	10/10/2024 05:38	1/22/2025 15:14	70332839009	Lead	<1.0	5	ug/L
KPS-013	HALLWAY DRINKING FOUNTAIN	10/10/2024 05:38	1/22/2025 15:15	70332839010	Lead	<1.0	5	ug/L
KPS-014	CLASSROOM 011 SINK	10/10/2024 05:36	1/22/2025 15:10	70332839007	Lead	4.8	5	ug/L
KPS-018	KITCHEN SINK KETTLE RIGHT	10/10/2024 05:30	1/22/2025 15:06	70332839005	Lead	7.7	5	ug/L
KPS-019	KITCHEN SINK # 2	10/10/2024 05:29	1/22/2025 15:04	70332839004	Lead	<1.0	5	ug/L
KPS-020	KITCHEN SINK # 3	10/10/2024 05:27	1/22/2025 14:58	70332839002	Lead	<1.0	5	ug/L
KPS-021	KITCHEN SINK # 4	10/10/2024 05:27	1/22/2025 15:03	70332839003	Lead	<1.0	5	ug/L
KPS-023	KITCHEN SINK # 5	10/10/2024 05:31	1/23/2025 09:33	70332839006	Lead	1,610	5	ug/L
KPS-026	CLASSROOM 112 SINK	10/10/2024 05:55	1/22/2025 15:32	70332839019	Lead	4.7	5	ug/L
KPS-027	CLASSROOM 110 SINK	10/10/2024 05:54	1/22/2025 15:31	70332839018	Lead	12.5	5	ug/L
KPS-034	NURSE OFFICE SINK	10/10/2024 05:51	1/22/2025 15:29	70332839017	Lead	<1.0	5	ug/L
KPS-036	CLASSROOM 109 SINK	10/10/2024 05:57	1/22/2025 15:34	70332839020	Lead	3.6	5	ug/L
KPS-037	CLASSROOM 111 SINK	10/10/2024 05:59	1/22/2025 18:04	70332839021	Lead	1.3	5	ug/L
KPS-038	CLASSROOM 113 SINK	10/10/2024 06:00	1/22/2025 15:36	70332839022	Lead	1.2	5	ug/L
KPS-042	FACULTY RM 115 SINK	10/10/2024 06:03	1/22/2025 15:52	70332839025	Lead	1.4	5	ug/L
KPS-043	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:01	1/22/2025 15:40	70332839023	Lead	<1.0	5	ug/L
KPS-044	HALLWAY BOTTLE FILLER	10/10/2024 06:01	1/22/2025 15:48	70332839024	Lead	<1.0	5	ug/L
KPS-054	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:12	1/22/2025 16:00	70332839030	Lead	<1.0	5	ug/L
KPS-055	HALLWAY BOTTLE FILLER	10/10/2024 06:12	1/22/2025 16:02	70332839031	Lead	<1.0	5	ug/L
KPS-056	OFFICE RM 219 SINK	10/10/2024 06:09	1/22/2025 15:59	70332839029	Lead	20.3	5	ug/L
KPS-060	HALLWAY BOTTLE FILLER	10/10/2024 06:06	1/22/2025 15:54	70332839026	Lead	<1.0	5	ug/L
KPS-061	HALLWAY DRINKING FOUNTAIN	10/10/2024 06:06	1/22/2025 15:56	70332839027	Lead	<1.0	5	ug/L
KPS-065	READING RM 224 SINK	10/10/2024 06:07	1/22/2025 15:57	70332839028	Lead	<1.0	5	ug/L
KPS-066	Custodial Office SINK	10/10/2024 05:37	1/22/2025 15:12	70332839008	Lead	3.6	5	ug/L
KPS-067	SPIGOT OFF MAIN	10/10/2024 05:25	1/22/2025 14:54	70332839001	Lead	2.9	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb



January 24, 2025

Pete Colucci
CiTi BOCES Oswego City School District
2 Buccaneer Blvd
Oswego, NY 13126

RE: Project: KPS-KINGSFORD PARK ELEM 10/10
Pace Project No.: 70332839

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen
michelle.cohen@pacelabs.com
516-370-6000
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District
CiTi BOCES Safety and, CiTi BOCES Oswego City School
District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-067								
Lab ID: 70332839001								
Collected: 10/10/24 05:25 Received: 01/15/25 06:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.9	ug/L	1.0	1		01/22/25 14:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-020								
Lab ID: 70332839002								
Collected: 10/10/24 05:27								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 14:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-021								
Lab ID: 70332839003								
Collected: 10/10/24 05:27								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 15:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-019								
Lab ID: 70332839004								
Collected: 10/10/24 05:29								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 15:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-018		Lab ID: 70332839005	Collected: 10/10/24 05:30	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.7	ug/L	1.0	1		01/22/25 15:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-023		Lab ID: 70332839006	Collected: 10/10/24 05:31	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1610	ug/L	5.0	5	01/22/25 07:20	01/23/25 09:33	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-014								
Lab ID: 70332839007								
Collected: 10/10/24 05:36								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.8	ug/L	1.0	1		01/22/25 15:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-066		Lab ID: 70332839008	Collected: 10/10/24 05:37	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.6	ug/L	1.0	1		01/22/25 15:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-012		Lab ID: 70332839009	Collected: 10/10/24 05:38	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-013		Lab ID: 70332839010	Collected: 10/10/24 05:38	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-008								
Lab ID: 70332839011								
Collected: 10/10/24 05:39								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	7.8	ug/L	1.0	1		01/22/25 15:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-007		Lab ID: 70332839012	Collected: 10/10/24 05:41	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.2	ug/L	1.0	1		01/22/25 15:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-006		Lab ID: 70332839013	Collected: 10/10/24 05:42	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-001		Lab ID: 70332839014	Collected: 10/10/24 05:44	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-005		Lab ID: 70332839015	Collected: 10/10/24 05:45	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-003								
Lab ID: 70332839016								
Collected: 10/10/24 05:47								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	10.7	ug/L	1.0	1		01/22/25 15:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-034		Lab ID: 70332839017	Collected: 10/10/24 05:51	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-027		Lab ID: 70332839018	Collected: 10/10/24 05:54	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	12.5	ug/L	1.0	1		01/22/25 15:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-026								
Lab ID: 70332839019								
Collected: 10/10/24 05:55								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.7	ug/L	1.0	1		01/22/25 15:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-036								
Lab ID: 70332839020								
Collected: 10/10/24 05:57								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.6	ug/L	1.0	1		01/22/25 15:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-037		Lab ID: 70332839021	Collected: 10/10/24 05:59	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.3	ug/L	1.0	1	01/22/25 07:20	01/22/25 18:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-038		Lab ID: 70332839022	Collected: 10/10/24 06:00	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		01/22/25 15:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-043		Lab ID: 70332839023	Collected: 10/10/24 06:01	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-044								
Lab ID: 70332839024								
Collected: 10/10/24 06:01								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 15:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-042								
Lab ID: 70332839025								
Collected: 10/10/24 06:03								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.4	ug/L	1.0	1		01/22/25 15:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-060		Lab ID: 70332839026	Collected: 10/10/24 06:06	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 15:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-061								
Lab ID: 70332839027								
Collected: 10/10/24 06:06								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 15:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KPS-065								
Lab ID: 70332839028								
Collected: 10/10/24 06:07								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 15:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-056		Lab ID: 70332839029	Collected: 10/10/24 06:09	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	20.3	ug/L	1.0	1		01/22/25 15:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-054		Lab ID: 70332839030	Collected: 10/10/24 06:12	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 16:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

Sample: KPS-055		Lab ID: 70332839031	Collected: 10/10/24 06:12	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 16:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

QC Batch:	381127	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332839001, 70332839002, 70332839003, 70332839004, 70332839005, 70332839007, 70332839008, 70332839009, 70332839010, 70332839011, 70332839012, 70332839013, 70332839014, 70332839015, 70332839016, 70332839017, 70332839018, 70332839019, 70332839020, 70332839022		

METHOD BLANK:	2000293	Matrix:	Water
Associated Lab Samples:	70332839001, 70332839002, 70332839003, 70332839004, 70332839005, 70332839007, 70332839008, 70332839009, 70332839010, 70332839011, 70332839012, 70332839013, 70332839014, 70332839015, 70332839016, 70332839017, 70332839018, 70332839019, 70332839020, 70332839022		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 14:48	

LABORATORY CONTROL SAMPLE:	2000294					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.1	104	85-115	

MATRIX SPIKE SAMPLE:	2000296						
Parameter	Units	70332839001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		2.9	50	51.9	98	70-130

MATRIX SPIKE SAMPLE:	2000298						
Parameter	Units	70332839002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		<1.0	50	48.8	97	70-130

SAMPLE DUPLICATE:	2000295					
Parameter	Units	70332839001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L		2.9	2.5	15	

SAMPLE DUPLICATE:	2000297					
Parameter	Units	70332839002 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L		<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

QC Batch:	381128	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332839023, 70332839024, 70332839025, 70332839026, 70332839027, 70332839028, 70332839029, 70332839030, 70332839031		

METHOD BLANK:	2000312	Matrix:	Water
Associated Lab Samples:	70332839023, 70332839024, 70332839025, 70332839026, 70332839027, 70332839028, 70332839029, 70332839030, 70332839031		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 15:37	

LABORATORY CONTROL SAMPLE:	2000313					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.7	101	85-115	

MATRIX SPIKE SAMPLE:	2000315						
Parameter	Units	70332839023 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.1	100	70-130	

MATRIX SPIKE SAMPLE:	2000317						
Parameter	Units	70332839024 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.2	94	70-130	

SAMPLE DUPLICATE:	2000314					
Parameter	Units	70332839023 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	2000316					
Parameter	Units	70332839024 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

QC Batch: 381079

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70332839006, 70332839021

METHOD BLANK: 2000018

Matrix: Water

Associated Lab Samples: 70332839006, 70332839021

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 17:58	

LABORATORY CONTROL SAMPLE & LCSD: 2000019

2000020

Parameter	Units	Spike Conc.	LCS Result	LCSD Result	LCS % Rec	LCSD % Rec	% Rec Limits	RPD	Max RPD	Qualifiers
Lead	ug/L	50	51.4	50.7	103	101	85-115	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: KPS-KINGSFORD PARK ELEM 10/10

Pace Project No.: 70332839

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: KPS-KINGSFORD PARK ELEM 10/10
 Pace Project No.: 70332839

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332839006	KPS-023	EPA 200.8	381079	EPA 200.8	381091
70332839021	KPS-037	EPA 200.8	381079	EPA 200.8	381091
70332839001	KPS-067	EPA 200.8	381127		
70332839002	KPS-020	EPA 200.8	381127		
70332839003	KPS-021	EPA 200.8	381127		
70332839004	KPS-019	EPA 200.8	381127		
70332839005	KPS-018	EPA 200.8	381127		
70332839007	KPS-014	EPA 200.8	381127		
70332839008	KPS-066	EPA 200.8	381127		
70332839009	KPS-012	EPA 200.8	381127		
70332839010	KPS-013	EPA 200.8	381127		
70332839011	KPS-008	EPA 200.8	381127		
70332839012	KPS-007	EPA 200.8	381127		
70332839013	KPS-006	EPA 200.8	381127		
70332839014	KPS-001	EPA 200.8	381127		
70332839015	KPS-005	EPA 200.8	381127		
70332839016	KPS-003	EPA 200.8	381127		
70332839017	KPS-034	EPA 200.8	381127		
70332839018	KPS-027	EPA 200.8	381127		
70332839019	KPS-026	EPA 200.8	381127		
70332839020	KPS-036	EPA 200.8	381127		
70332839022	KPS-038	EPA 200.8	381127		
70332839023	KPS-043	EPA 200.8	381128		
70332839024	KPS-044	EPA 200.8	381128		
70332839025	KPS-042	EPA 200.8	381128		
70332839026	KPS-060	EPA 200.8	381128		
70332839027	KPS-061	EPA 200.8	381128		
70332839028	KPS-065	EPA 200.8	381128		
70332839029	KPS-056	EPA 200.8	381128		
70332839030	KPS-054	EPA 200.8	381128		
70332839031	KPS-055	EPA 200.8	381128		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



WO#: 70332839



1 of 3

CHAIN-OF-CUSTODY / AN
The Chain-of-Custody is a LEGAL DOCUMENT

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions

Section A Required Client Information: Company: Oswego City School District
Address: 2 Buccaneer Blvd, Oswego NY 13126
Phone: 315-341-2906 Fax
Email: Pcollucc2@oswego.org

Section B Required Project Information: Report To: Ian Rowberry (irowberry@oswego.org)
Copy To: Aleisha Hartford (ahartford@citiboces.org)
Purchase Order #: safetvandrisk@citiboces.org
Project Name: KPS- Kingsford Park Elementary
Project #:

Section C Invoice Information: Attention: Pete Colucci
Company Name: Oswego City School District
Address: 2 Buccaneer Blvd, Oswego NY 13126
Pace Quote: alexandria.correa@paceabs.com
Pace Project Manager:
Pace Profile #:

Regulatory Agency: NY
State / Location: NY

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES		Analyses Test Y/N	LEAD BY 200.8	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE TIME	END DATE TIME				H2SO4	HNO3				
1	DW	DW	10/10 0525		DW G			X		X			
2	DW	WT	10/10 0527		DW G			X		X			
3	DW	WP	10/10 0527		DW G			X		X			
4	DW	WP	10/10 0529		DW G			X		X			
5	DW	WP	10/10 0530		DW G			X		X			
6	DW	WP	10/10 0531		DW G			X		X			
7	DW	WP	10/10 0536		DW G			X		X			
8	DW	WP	10/10 0537		DW G			X		X			
9	DW	WP	10/10 0538		DW G			X		X			
10	DW	WP	10/10 0538		DW G			X		X			
11	DW	WP	10/10 0539		DW G			X		X			
12	DW	WP	10/10 0541		DW G			X		X			

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	<i>[Signature]</i>	11/8	12P	<i>Bin Patricia</i>	10/8	12P	
	<i>Bin Patricia</i>	1/14	12:15	<i>[Signature]</i>	1/14	12:15	
	<i>[Signature]</i>	1/14	17:00	<i>AEB Pace LI</i>	1/15/25	6:00	
	<i>[Signature]</i>						

SAMPLER NAME AND SIGNATURE
 PRINT Name of SAMPLER: *Aleisha Hartford*
 SIGNATURE of SAMPLER: *[Signature]* DATE Signed: *[Date]*



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately. Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at <https://info.pacelabs.com/hubfs/pas-standard-terms.pdf>.

Section A

Required Client Information:
 Company: Oswego City School District
 Address: 2 Buccaneer Blvd. Oswego NY 13126
 Email: Pcolucci2@oswego.org Fax
 Phone: 315-341-2306
 Requested Due Date:

Required Project Information:
 Report To: Ian Rowberry (irowberry@oswego.org)
 Copy To: Aleisha Hartford (ahartford@citiboces.org)
safetvandrisk@citiboces.org
 Purchase Order #:
 Project Name: KPS- Kingsford Park Elementary
 Project #:

Invoice Information:
 Attention: Pete Colucci
 Company Name: Oswego City School District
 Address: 2 Buccaneer Blvd. Oswego NY 13126
 Pace Quote:
 Pace Project Manager: alexandria.correa@pacelabs.com
 Pace Profile #:

Regulatory Agency
 State / Location
 NY

Section B

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES		ANALYSES TEST Y/N	Requested Analysis Filtered (Y/N)	TEMP in C	Received on Ice (Y/N)	Custody Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)	
			START	END				H2SO4	HNO3								HCl
25	Drinking Water	DW	DATE	TIME	DWG					X							
			10/10	0603						X							
26	Waste Water	WW	DATE	TIME	DWG					X							
			10/10	0606						X							
27	Water Product	P	DATE	TIME	DWG					X							
			10/10	0606						X							
28	Oil	OL	DATE	TIME	DWG					X							
			10/10	0607						X							
29	Wipes	WP	DATE	TIME	DWG					X							
			10/10	0609						X							
30	Air	AR	DATE	TIME	DWG					X							
			10/10	0612						X							
31	Other Tissue	OT	DATE	TIME	DWG					X							
			10/10	0612						X							
32			DATE	TIME	DWG					X							
			10/10							X							
33			DATE	TIME	DWG					X							
			10/10							X							
34			DATE	TIME	DWG					X							
			10/10							X							
35			DATE	TIME	DWG					X							
			10/10							X							
36			DATE	TIME	DWG					X							
			10/10							X							

Section C

ADDITIONAL COMMENTS

RELINQUISHED BY / AFFILIATION: *Alexandra Hartford* DATE: 11/8 TIME: 12P

ACCEPTED BY / AFFILIATION: *Alexandra Hartford* DATE: 1/14 TIME: 12:15

DATE SIGNED: *Alexandra Hartford*

RESIDUAL CHLORINE (Y/N)

TEMP in C

Received on Ice (Y/N)

Custody Sealed (Y/N)

Cooler (Y/N)

Samples Intact (Y/N)

DC#_Title: Excel Form Template
Effective Date:

WO#: 70332839

Client Name:

OswegoCityCS

Project #

PM: MC1

Due Date: 01/24/25

Courier: Fed Ex UPS USPS Client Commercial Pacd Other

CLIENT: OswegoCityCS

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: THZ11 Correction Factor: 0 Samples on ice, cooling process has begun

Cooler Temperature (°C): 19.1 Cooler Temperature Corrected (°C): 19.1 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: AEB 1/15/25

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL WT OIL OTHER	

Date and Initials of person checking preservation: AEB 1/15/25

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # 213624	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.