

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
MIN 001	Art Room Sink	10/8/2024 07:12	1/22/2025 13:26	70332829016	Lead	1.2	5	ug/L
MIN 010	Gym drinking fountain	10/8/2024 07:17	1/22/2025 13:30	70332829018	Lead	15.2	5	ug/L
MIN 011	Room 119 Sink	10/8/2024 07:23	1/22/2025 13:40	70332829023	Lead	<1.0	5	ug/L
MIN 012	CLASS ROOM 130 Sink	10/8/2024 07:23	1/22/2025 13:39	70332829022	Lead	1.1	5	ug/L
MIN 014	CLASSROOM 128 Sink	10/8/2024 07:22	1/22/2025 13:37	70332829021	Lead	<1.0	5	ug/L
MIN 017	CLASSROOM 126 Sink	10/8/2024 07:21	1/22/2025 13:33	70332829020	Lead	<1.0	5	ug/L
MIN 024	Room 114 Classroom Sink	10/8/2024 07:20	1/22/2025 13:31	70332829019	Lead	6.4	5	ug/L
MIN 025A	HALLWAY DRINKING FOUNTAIN	10/8/2024 07:16	1/22/2025 13:28	70332829017	Lead	<1.0	5	ug/L
MIN 025B	HALLWAY DRINKING FOUNTAIN	1/13/2025 15:45	1/22/2025 14:46	70332829053	Lead	<1.0	5	ug/L
MIN 026	Nurse Exam Sink	10/8/2024 07:12	1/22/2025 13:22	70332829015	Lead	2.8	5	ug/L
MIN 028	Room 102B Sink	10/8/2024 07:09	1/22/2025 13:14	70332829014	Lead	13.5	5	ug/L
MIN 031	CAFE BOTTLE FILLER	10/8/2024 06:57	1/22/2025 13:00	70332829007	Lead	<1.0	5	ug/L
MIN 032	CafE DRINKING FOUNTAIN	10/8/2024 06:56	1/22/2025 13:02	70332829008	Lead	<1.0	5	ug/L
MIN 037	Kitchen NE Sink	10/8/2024 06:54	1/22/2025 12:54	70332829005	Lead	6.1	5	ug/L
MIN 040	Kettle filler	10/8/2024 06:54	1/22/2025 12:53	70332829004	Lead	<1.0	5	ug/L
MIN 041	Kettle filler	10/8/2024 06:53	1/22/2025 12:51	70332829003	Lead	2.0	5	ug/L
MIN 042	Kitchen Storage Sink	10/8/2024 06:52	1/22/2025 12:49	70332829002	Lead	1.8	5	ug/L
MIN 043	kitchen sink	10/8/2024 06:51	1/22/2025 12:48	70332829001	Lead	1.9	5	ug/L
MIN 047	Faculty Room Sink	10/8/2024 06:56	1/22/2025 12:56	70332829006	Lead	4.0	5	ug/L
MIN 048	Room 145 Sink	10/8/2024 07:00	1/22/2025 13:07	70332829011	Lead	5.6	5	ug/L
MIN 049	Room 146 Sink	10/8/2024 07:02	1/22/2025 13:08	70332829012	Lead	5.6	5	ug/L
MIN 050	Cafe DRINKING FOUNTAIN	10/8/2024 07:00	1/22/2025 13:05	70332829010	Lead	<1.0	5	ug/L
MIN 051	CafE BOTTLE FILLER	10/8/2024 07:00	1/22/2025 13:03	70332829009	Lead	<1.0	5	ug/L
MIN 055	Band Room Sink	10/8/2024 07:06	1/22/2025 13:10	70332829013	Lead	<1.0	5	ug/L
MIN 057	Room 201 Classroom Sink	10/8/2024 07:39	1/22/2025 14:19	70332829038	Lead	6.4	5	ug/L
MIN 058	Room 203 Classroom Sink	10/8/2024 07:38	1/22/2025 14:16	70332829036	Lead	2.4	5	ug/L
MIN 059	Room 205 Classroom Sink	10/8/2024 07:37	1/22/2025 14:04	70332829034	Lead	3.0	5	ug/L
MIN 064	HALLWAY BOTTLE FILLER	10/8/2024 07:35	1/22/2025 13:58	70332829032	Lead	<1.0	5	ug/L
MIN 064	HALLWAY DRINKING FOUNTAIN	1/7/2025 14:50	1/22/2025 14:44	70332829052	Lead	<1.0	5	ug/L
MIN 069	Room 213 Classroom Sink	10/8/2024 07:33	1/22/2025 13:52	70332829030	Lead	1.4	5	ug/L
MIN 070	Room 222 Classroom Sink	10/8/2024 07:26	1/22/2025 13:42	70332829024	Lead	1.8	5	ug/L

MIN 071	Room 220 Classroom Sink	10/8/2024 07:27	1/22/2025 13:44	70332829025	Lead	<1.0	5	ug/L
MIN 072	Room 218 Classroom Sink	10/8/2024 07:29	1/22/2025 13:45	70332829026	Lead	<1.0	5	ug/L
MIN 073	Room 216 Classroom Sink	10/8/2024 07:32	1/22/2025 13:47	70332829027	Lead	<1.0	5	ug/L
MIN 074	Room 214 Classroom Sink	10/8/2024 07:31	1/22/2025 13:48	70332829028	Lead	<1.0	5	ug/L
MIN 075	Room 212 Classroom Sink	10/8/2024 07:33	1/22/2025 13:50	70332829029	Lead	4.4	5	ug/L
MIN 076	Room 208 Classroom Sink	10/8/2024 07:33	1/22/2025 13:56	70332829031	Lead	<1.0	5	ug/L
MIN 077	Room 206 Classroom Sink	10/8/2024 07:36	1/22/2025 13:59	70332829033	Lead	4.4	5	ug/L
MIN 078	Room 204 Classroom Sink	10/8/2024 07:37	1/22/2025 14:08	70332829035	Lead	4.0	5	ug/L
MIN 079	Room 202 Classroom Sink	10/8/2024 07:39	1/22/2025 14:17	70332829037	Lead	2.0	5	ug/L
MIN 080	HALLWAY DRINKING FOUNTAIN	1/7/2025 14:53	1/22/2025 14:43	70332829051	Lead	<1.0	5	ug/L
MIN 081	HALLWAY BOTTLE FILLER	10/8/2024 07:43	1/22/2025 14:24	70332829041	Lead	<1.0	5	ug/L
MIN 085	HALLWAY BOTTLE FILLER	1/7/2025 14:53	1/22/2025 14:41	70332829050	Lead	<1.0	5	ug/L
MIN 086	HALLWAY DRINKING FOUNTAIN	10/8/2024 07:43	1/22/2025 14:21	70332829039	Lead	<1.0	5	ug/L
MIN 087	Room 230 Classroom Sink	10/8/2024 07:45	1/22/2025 14:25	70332829042	Lead	4.8	5	ug/L
MIN 088	Room 231 Classroom Sink	10/8/2024 07:46	1/22/2025 14:29	70332829044	Lead	11.5	5	ug/L
MIN 089	Room 232 Classroom Sink	10/8/2024 07:46	1/22/2025 14:27	70332829043	Lead	2.9	5	ug/L
MIN 090	Room 234 Classroom Sink	10/8/2024 07:47	1/22/2025 14:22	70332829040	Lead	3.1	5	ug/L
MIN 091	Room 235 Classroom Sink	10/8/2024 07:49	1/22/2025 14:33	70332829045	Lead	5.1	5	ug/L
MIN 092	Room 237 Classroom Sink	10/8/2024 07:49	1/22/2025 14:35	70332829046	Lead	4.9	5	ug/L
MIN 093	Room 238 Classroom Sink	10/8/2024 07:53	1/22/2025 14:36	70332829047	Lead	16.2	5	ug/L
MIN 094	Room 239 Classroom Sink	10/8/2024 07:51	1/22/2025 14:38	70332829048	Lead	15.6	5	ug/L
MIN 095	spigot off main	10/8/2024 09:00	1/22/2025 14:40	70332829049	Lead	64.1	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb



January 24, 2025

Pete Colucci  
CiTi BOCES Oswego City School District  
2 Buccaneer Blvd  
Oswego, NY 13126

RE: Project: MINETTO 10/8  
Pace Project No.: 70332829

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen  
michelle.cohen@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District  
CiTi BOCES Safety and, CiTi BOCES Oswego City School  
District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: MINETTO 10/8

Pace Project No.: 70332829

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 043		Lab ID: 70332829001	Collected: 10/08/24 06:51	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>1.9</b>	ug/L	1.0	1		01/22/25 12:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 042		Lab ID: 70332829002	Collected: 10/08/24 06:52	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		01/22/25 12:49	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 041		Lab ID: 70332829003	Collected: 10/08/24 06:53	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		01/22/25 12:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 040</b>								
<b>Lab ID: 70332829004</b>								
Collected: 10/08/24 06:54								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 12:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 037		Lab ID: 70332829005	Collected: 10/08/24 06:54	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.1</b>	ug/L	1.0	1		01/22/25 12:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 047		Lab ID: 70332829006	Collected: 10/08/24 06:56	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.0</b>	ug/L	1.0	1		01/22/25 12:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 031		Lab ID: 70332829007	Collected: 10/08/24 06:57	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 032</b>								
<b>Lab ID: 70332829008</b>								
Collected: 10/08/24 06:56 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 13:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 051		Lab ID: 70332829009	Collected: 10/08/24 07:00	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 050		Lab ID: 70332829010	Collected: 10/08/24 07:00	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 048</b>								
<b>Lab ID: 70332829011</b>								
Collected: 10/08/24 07:00 Received: 01/15/25 06:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	5.6	ug/L	1.0	1		01/22/25 13:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 049		Lab ID: 70332829012	Collected: 10/08/24 07:02	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>5.6</b>	ug/L	1.0	1		01/22/25 13:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 055		Lab ID: 70332829013	Collected: 10/08/24 07:06	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 028</b>								
<b>Lab ID: 70332829014</b>								
Collected: 10/08/24 07:09								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	13.5	ug/L	1.0	1		01/22/25 13:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 026		Lab ID: 70332829015	Collected: 10/08/24 07:12	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.8</b>	ug/L	1.0	1		01/22/25 13:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 001		Lab ID: 70332829016	Collected: 10/08/24 07:12	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.2	ug/L	1.0	1		01/22/25 13:26	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 025A		Lab ID: 70332829017	Collected: 10/08/24 07:16	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 010		Lab ID: 70332829018	Collected: 10/08/24 07:17	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>15.2</b>	ug/L	1.0	1		01/22/25 13:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 024</b>								
<b>Lab ID: 70332829019</b>								
Collected: 10/08/24 07:20								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	6.4	ug/L	1.0	1		01/22/25 13:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 017		Lab ID: 70332829020	Collected: 10/08/24 07:21	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 014</b>								
<b>Lab ID: 70332829021</b>								
Collected: 10/08/24 07:22								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 13:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 012</b>								
<b>Lab ID: 70332829022</b>								
Collected: 10/08/24 07:23								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.1	ug/L	1.0	1		01/22/25 13:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 011		Lab ID: 70332829023	Collected: 10/08/24 07:23	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 070		Lab ID: 70332829024	Collected: 10/08/24 07:26	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		01/22/25 13:42	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 071		Lab ID: 70332829025	Collected: 10/08/24 07:27	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 072		Lab ID: 70332829026	Collected: 10/08/24 07:29	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 073		Lab ID: 70332829027	Collected: 10/08/24 07:32	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:47	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 074</b>								
<b>Lab ID: 70332829028</b>								
Collected: 10/08/24 07:31								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 13:48	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 075</b>								
<b>Lab ID: 70332829029</b>								
Collected: 10/08/24 07:33								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.4	ug/L	1.0	1		01/22/25 13:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 069		Lab ID: 70332829030	Collected: 10/08/24 07:33	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		01/22/25 13:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 076		Lab ID: 70332829031	Collected: 10/08/24 07:33	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 13:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 064</b>								
<b>Lab ID: 70332829032</b>								
Collected: 10/08/24 07:35								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 13:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 077		Lab ID: 70332829033	Collected: 10/08/24 07:36	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.4</b>	ug/L	1.0	1		01/22/25 13:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 059		Lab ID: 70332829034	Collected: 10/08/24 07:37	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>3.0</b>	ug/L	1.0	1		01/22/25 14:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 078		Lab ID: 70332829035	Collected: 10/08/24 07:37	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.0</b>	ug/L	1.0	1		01/22/25 14:08	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 058		Lab ID: 70332829036	Collected: 10/08/24 07:38	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.4</b>	ug/L	1.0	1		01/22/25 14:16	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 079		Lab ID: 70332829037	Collected: 10/08/24 07:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.0</b>	ug/L	1.0	1		01/22/25 14:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 057		Lab ID: 70332829038	Collected: 10/08/24 07:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.4</b>	ug/L	1.0	1		01/22/25 14:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 086</b>								
<b>Lab ID: 70332829039</b>								
Collected: 10/08/24 07:43								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 14:21	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 090		Lab ID: 70332829040	Collected: 10/08/24 07:47	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.1	ug/L	1.0	1		01/22/25 14:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 081		Lab ID: 70332829041	Collected: 10/08/24 07:43	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 14:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 087		Lab ID: 70332829042	Collected: 10/08/24 07:45	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.8</b>	ug/L	1.0	1		01/22/25 14:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 089		Lab ID: 70332829043	Collected: 10/08/24 07:46	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.9</b>	ug/L	1.0	1		01/22/25 14:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 088</b>								
<b>Lab ID: 70332829044</b>								
Collected: 10/08/24 07:46								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	11.5	ug/L	1.0	1		01/22/25 14:29	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 091		Lab ID: 70332829045	Collected: 10/08/24 07:49	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	5.1	ug/L	1.0	1		01/22/25 14:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 092		Lab ID: 70332829046	Collected: 10/08/24 07:49	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>4.9</b>	ug/L	1.0	1		01/22/25 14:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 093		Lab ID: 70332829047	Collected: 10/08/24 07:53	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>16.2</b>	ug/L	1.0	1		01/22/25 14:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 094		Lab ID: 70332829048	Collected: 10/08/24 07:51	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>15.6</b>	ug/L	1.0	1		01/22/25 14:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 095		Lab ID: 70332829049	Collected: 10/08/24 09:00	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>64.1</b>	ug/L	1.0	1		01/22/25 14:40	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 085		Lab ID: 70332829050	Collected: 01/07/25 14:53	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 14:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 080</b>								
<b>Lab ID: 70332829051</b>								
Collected: 01/07/25 14:53								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 14:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: MIN 064</b>								
<b>Lab ID: 70332829052</b>								
Collected: 01/07/25 14:50								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 14:44	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: MINETTO 10/8

Pace Project No.: 70332829

Sample: MIN 025B		Lab ID: 70332829053	Collected: 01/13/25 15:45	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 14:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: MINETTO 10/8

Pace Project No.: 70332829

QC Batch: 381106 Analysis Method: EPA 200.8  
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water  
 Laboratory: Pace Analytical Services - Melville  
 Associated Lab Samples: 70332829001, 70332829002, 70332829003, 70332829004, 70332829005, 70332829006, 70332829007, 70332829008, 70332829009, 70332829010, 70332829011, 70332829012, 70332829013

METHOD BLANK: 2000133 Matrix: Water  
 Associated Lab Samples: 70332829001, 70332829002, 70332829003, 70332829004, 70332829005, 70332829006, 70332829007, 70332829008, 70332829009, 70332829010, 70332829011, 70332829012, 70332829013

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 12:25	

LABORATORY CONTROL SAMPLE: 2000134

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.1	100	85-115	

MATRIX SPIKE SAMPLE: 2000136

Parameter	Units	70332843059 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.3	50	59.8	115	70-130	

MATRIX SPIKE SAMPLE: 2000138

Parameter	Units	70332843060 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	7.0	50	61.8	110	70-130	

SAMPLE DUPLICATE: 2000135

Parameter	Units	70332843059 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	2.3	2.3	0	

SAMPLE DUPLICATE: 2000137

Parameter	Units	70332843060 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	7.0	6.9	2	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: MINETTO 10/8

Pace Project No.: 70332829

QC Batch:	381107	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332829014, 70332829015, 70332829016, 70332829017, 70332829018, 70332829019, 70332829020, 70332829021, 70332829022, 70332829023, 70332829024, 70332829025, 70332829026, 70332829027, 70332829028, 70332829029, 70332829030, 70332829031, 70332829032, 70332829033		

METHOD BLANK:	2000139	Matrix:	Water
Associated Lab Samples:	70332829014, 70332829015, 70332829016, 70332829017, 70332829018, 70332829019, 70332829020, 70332829021, 70332829022, 70332829023, 70332829024, 70332829025, 70332829026, 70332829027, 70332829028, 70332829029, 70332829030, 70332829031, 70332829032, 70332829033		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 13:11	

LABORATORY CONTROL SAMPLE:	2000140					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.0	102	85-115	

MATRIX SPIKE SAMPLE:	2000142						
Parameter	Units	70332829014 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	13.5	50	68.3	110	70-130	

MATRIX SPIKE SAMPLE:	2000144						
Parameter	Units	70332829015 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	2.8	50	50.9	96	70-130	

SAMPLE DUPLICATE:	2000141					
Parameter	Units	70332829014 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	13.5	13.6	1		

SAMPLE DUPLICATE:	2000143					
Parameter	Units	70332829015 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	2.8	2.8	1		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: MINETTO 10/8

Pace Project No.: 70332829

QC Batch:	381126	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332829034, 70332829035, 70332829036, 70332829037, 70332829038, 70332829039, 70332829040, 70332829041, 70332829042, 70332829043, 70332829044, 70332829045, 70332829046, 70332829047, 70332829048, 70332829049, 70332829050, 70332829051, 70332829052, 70332829053		

METHOD BLANK:	2000282	Matrix:	Water
Associated Lab Samples:	70332829034, 70332829035, 70332829036, 70332829037, 70332829038, 70332829039, 70332829040, 70332829041, 70332829042, 70332829043, 70332829044, 70332829045, 70332829046, 70332829047, 70332829048, 70332829049, 70332829050, 70332829051, 70332829052, 70332829053		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 14:01	

LABORATORY CONTROL SAMPLE:	2000283					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE:	2000285						
Parameter	Units	70332829034 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		50	53.4	101	70-130	

MATRIX SPIKE SAMPLE:	2000287						
Parameter	Units	70332829035 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		50	52.5	97	70-130	

SAMPLE DUPLICATE:	2000284					
Parameter	Units	70332829034 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	3.0	3.0	0		

SAMPLE DUPLICATE:	2000286					
Parameter	Units	70332829035 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	4.0	3.9	2		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: MINETTO 10/8

Pace Project No.: 70332829

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: MINETTO 10/8

Pace Project No.: 70332829

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332829001	MIN 043	EPA 200.8	381106		
70332829002	MIN 042	EPA 200.8	381106		
70332829003	MIN 041	EPA 200.8	381106		
70332829004	MIN 040	EPA 200.8	381106		
70332829005	MIN 037	EPA 200.8	381106		
70332829006	MIN 047	EPA 200.8	381106		
70332829007	MIN 031	EPA 200.8	381106		
70332829008	MIN 032	EPA 200.8	381106		
70332829009	MIN 051	EPA 200.8	381106		
70332829010	MIN 050	EPA 200.8	381106		
70332829011	MIN 048	EPA 200.8	381106		
70332829012	MIN 049	EPA 200.8	381106		
70332829013	MIN 055	EPA 200.8	381106		
70332829014	MIN 028	EPA 200.8	381107		
70332829015	MIN 026	EPA 200.8	381107		
70332829016	MIN 001	EPA 200.8	381107		
70332829017	MIN 025A	EPA 200.8	381107		
70332829018	MIN 010	EPA 200.8	381107		
70332829019	MIN 024	EPA 200.8	381107		
70332829020	MIN 017	EPA 200.8	381107		
70332829021	MIN 014	EPA 200.8	381107		
70332829022	MIN 012	EPA 200.8	381107		
70332829023	MIN 011	EPA 200.8	381107		
70332829024	MIN 070	EPA 200.8	381107		
70332829025	MIN 071	EPA 200.8	381107		
70332829026	MIN 072	EPA 200.8	381107		
70332829027	MIN 073	EPA 200.8	381107		
70332829028	MIN 074	EPA 200.8	381107		
70332829029	MIN 075	EPA 200.8	381107		
70332829030	MIN 069	EPA 200.8	381107		
70332829031	MIN 076	EPA 200.8	381107		
70332829032	MIN 064	EPA 200.8	381107		
70332829033	MIN 077	EPA 200.8	381107		
70332829034	MIN 059	EPA 200.8	381126		
70332829035	MIN 078	EPA 200.8	381126		
70332829036	MIN 058	EPA 200.8	381126		
70332829037	MIN 079	EPA 200.8	381126		
70332829038	MIN 057	EPA 200.8	381126		
70332829039	MIN 086	EPA 200.8	381126		
70332829040	MIN 090	EPA 200.8	381126		
70332829041	MIN 081	EPA 200.8	381126		
70332829042	MIN 087	EPA 200.8	381126		
70332829043	MIN 089	EPA 200.8	381126		
70332829044	MIN 088	EPA 200.8	381126		
70332829045	MIN 091	EPA 200.8	381126		
70332829046	MIN 092	EPA 200.8	381126		
70332829047	MIN 093	EPA 200.8	381126		
70332829048	MIN 094	EPA 200.8	381126		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: MINETTO 10/8

Pace Project No.: 70332829

---

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332829049	MIN 095	EPA 200.8	381126		
70332829050	MIN 085	EPA 200.8	381126		
70332829051	MIN 080	EPA 200.8	381126		
70332829052	MIN 064	EPA 200.8	381126		
70332829053	MIN 025B	EPA 200.8	381126		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.









# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately. Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at <https://info.pacelabs.com/hubs/pas-standard-terms.pdf>.

Section C Page: 3 Of 4

### Section A

**Required Client Information:**  
 Company: Oswego City School District  
 Address: 2 Buccaneer Blvd. Oswego NY 13126  
 Email: [Pcolucc2@oswego.org](mailto:Pcolucc2@oswego.org) | Fax  
 Phone: 315-341-2906  
 Requested Due Date:

### Section B

**Required Project Information:**  
 Report To: Ian Rowberry (irowbarr@oswego.org)  
 Copy To: Aleisha Hartford (ahartford@citiboces.org)  
[safeyandrisk@citiboces.org](mailto:safeyandrisk@citiboces.org)  
 Purchase Order #:  
 Project Name: **Mineetto**  
 Project #:

### Section C

**Invoice Information:**  
 Attention: Pete Colucci  
 Company Name: Oswego City School District  
 Address: 2 Buccaneer Blvd. Oswego NY 13126  
 Pace Quote:  
 Pace Project Manager: [alexandria.conrea@pacelabs.com](mailto:alexandria.conrea@pacelabs.com)  
 Pace Profile #: NY

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	RELINQUISHED BY / AFFILIATION		DATE		TIME	ACCEPTED BY / AFFILIATION	DATE		TIME	SAMPLE CONDITIONS
			START	END			DATE	TIME	DATE	TIME			DATE	TIME		
25	Drinking Water	DW	10/5/24	0727	DWG											
26	Water	WT	10/24	0729	DWG											
27	Waste Water Product	WWP	10/24	0732	DWG											
28	Oil	OL		0731	DWG											
29	Wipe	WP		0733	DWG											
30	Air	AR		0733	DWG											
31	Other	OT		0733	DWG											
32	Tissue	TS		0735	DWG											
33				0736	DWG											
34				0737	DWG											
35				0737	DWG											
36				0738	DWG											

**Requested Analysis Filtered (Y/N)**

Analyses Test	Y/N
LEAD BY 200.8	X
Residual Chlorine (Y/N)	

**Preservatives**  
 H2SO4, HNO3, HCl, NaOH, Na2SO3, Methanol, Other

**# OF CONTAINERS**  
 Unpreserved

**SAMPLE TEMP AT COLLECTION**

**RELINQUISHED BY / AFFILIATION**  
 AL...  
 B...  
 K...  
 AEB

**DATE**  
 10/8 12:15  
 11/4 12:15  
 11/4 17:00

**ACCEPTED BY / AFFILIATION**  
 B...  
 A...  
 A...

**DATE**  
 10/8 12:15  
 11/4 12:15  
 11/4 17:00

**SAMPLER NAME AND SIGNATURE**  
 PRINT Name of SAMPLER: Aleisha Hartford  
 SIGNATURE of SAMPLER: [Signature]  
 DATE Signed: [Date]

Page 64 of 67



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately. Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at <https://info.pacelabs.com/hubfs/pas-standard-terms.pdf>.

Page: 4 of 45

### Section A

**Required Client Information:**  
 Company: Oswego City School District  
 Address: 2 Buccaneer Blvd. Oswego NY 13126  
 Email: Pcolucc2@oswego.org  
 Phone: 315-341-2906 Fax: \_\_\_\_\_  
 Requested Due Date: \_\_\_\_\_

**Required Project Information:**  
 Report To: Ian Rowberry (rowberry@oswego.org)  
 Copy To: Aleisha Hartford (ahartford@citiboces.org)  
safelyandrisk@citiboces.org  
 Project Name: Minedo  
 Purchase Order #: \_\_\_\_\_  
 Project #: \_\_\_\_\_

**Invoice Information:**  
 Attention: Pete Colucci  
 Company Name: Oswego City School District  
 Address: 2 Buccaneer Blvd. Oswego NY 13126  
 Pace Project Manager: alexandria.correa@pacelabs.com  
 Pace Quote: \_\_\_\_\_  
 Regulatory Agency: \_\_\_\_\_  
 State / Location: NY

### Section B

**MATRIX**  
 Drinking Water  
 Water  
 Waste Water  
 Product  
 Soil/Solid  
 Oil  
 Wipe  
 Air  
 Other  
 Tissue

**CODE**  
 DW  
 WT  
 WW  
 P  
 SL  
 OL  
 WP  
 AR  
 OT  
 TS

**SAMPLE ID**  
 One Character per box.  
 (A-Z, 0-9 /, -)

Sample Ids must be unique

### Section C

ITEM #	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	SAMPLE TEMP AT COLLECTION		# OF CONTAINERS	Preservatives		Analyses Test	Requested Analysis Filtered (Y/N)	TEMP in C	Received on Ice (Y/N)	Custody Sealed (Y/N)	Samples Intact (Y/N)
		START DATE	END TIME		H2SO4	HNO3		HCl	NaOH						
37	DWG	10/24/16	0739					X							
38	DWG	10/24/16	0739					X							
39	DWG	10/24/16	0743					X							
40	DWG	10/24/16	0749					X							
41	DWG	10/8/16	0743					X							
42	DWG	10/8/16	0745					X							
43	DWG	10/8/16	0746					X							
44	DWG	10/8/16	0746					X							
45	DWG	10/8/16	0749					X							
46	DWG	10/8/16	0749					X							
47	DWG	10/8/16	0753					X							
48	DWG	10/8/16	0751					X							

  

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>Alexandra Hartford</i>	11/8	12P	<i>Jim Patrick</i>	11/8	12P	
<i>Bambalich</i>	1/14	1214	<i>[Signature]</i>	1/14	1215	
<i>[Signature]</i>	1/14	1700	<i>AEB Pace LT</i>	1/15/25	600	

  

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER: <i>Aleisha Hartford</i>	DATE Signed: _____
SIGNATURE of SAMPLER: <i>[Signature]</i>	



Effective Date:

Client Name:

Oswego City CS

Project #

WO#: 70332829

PM: MC1

Due Date: 01/24/25

CLIENT: OswegoCityCS

Courier:  Fed Ex  UPS  USPS  Client  Commercial  Pac  Other

Tracking #:

Custody Seal on Cooler/Box Present:  Yes  No Seals intact:  Yes  No Temperature Blank Present:  Yes  No

Packing Material:  Bubble Wrap  Bubble Bags  Ziplo  Non  Other Type of Ice: Wet Blue  None

Thermometer Used: THC11 Correction Factor: 0  Samples on ice, cooling process has begun

Cooler Temperature (°C): 19.1 Cooler Temperature Corrected (°C): 19.1 Date/Time 5035A kits placed in freezer \_\_\_\_\_

Temp should be above freezing to 6.0°C

USDA Regulated Soil  N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)?  Yes  No

Did samples originate from a foreign source including Hawaii and Puerto Rico?  Yes  No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: AOB 1/15/25

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <input checked="" type="checkbox"/> WT <input type="checkbox"/> OIL OTHER	

Date and Initials of person checking preservation: AOB 1/15/25

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO <sub>3</sub> <input type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>213624</u>	Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO <sub>3</sub> , H <sub>2</sub> SO <sub>4</sub> , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide)	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot #	
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	15. Positive for Sulfide? Y N
Lead Acetate Strips Lot #	
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.