

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
OHS-002	IT KITCHEN SINK	10/9/2024 05:10	1/22/2025 11:56	70332843045	Lead	3.3
OHS-004	STORAGE RM 101G SINK	10/9/2024 05:09	1/22/2025 11:55	70332843044	Lead	1.0
OHS-008	HALLWAY BOTTLE FILLER	10/9/2024 05:05	1/22/2025 11:45	70332843040	Lead	<1.0
OHS-009	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:05	1/22/2025 11:50	70332843041	Lead	<1.0
OHS-010	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:06	1/22/2025 11:53	70332843043	Lead	<1.0
OHS-019	MAIN OFFICE CONF RM SINK	10/9/2024 05:12	1/22/2025 11:58	70332843046	Lead	<1.0
OHS-020	CHORUS RM BOTTLE FILLER	10/9/2024 04:56	1/22/2025 11:20	70332843032	Lead	<1.0
OHS-021	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:56	1/22/2025 11:22	70332843033	Lead	<1.0
OHS-024	HALLWAY DRINKING FOUNTAIN	10/9/2024 04:55	1/22/2025 11:17	70332843030	Lead	<1.0
OHS-025	ORCHESTRA BOTTLE FILLER	10/9/2024 04:55	1/22/2025 11:19	70332843031	Lead	<1.0
OHS-029	BAND RM SINK	10/9/2024 05:01	1/22/2025 11:30	70332843036	Lead	<1.0
OHS-030	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:00	1/22/2025 11:27	70332843034	Lead	<1.0
OHS-031	FITNESS BOTTLE FILLER	10/9/2024 05:00	1/22/2025 11:28	70332843035	Lead	<1.0
OHS-033	FITNESS DRINKING FOUNTAIN	10/9/2024 05:03	1/22/2025 11:33	70332843038	Lead	<1.0
OHS-034	HALLWAY BOTTLE FILLER	10/9/2024 05:03	1/22/2025 11:38	70332843039	Lead	<1.0
OHS-036	FITNESS CTR ICE MACHINE	10/9/2024 05:05	1/22/2025 11:51	70332843042	Lead	<1.0
OHS-037	FITNESS CTR OFFICE 117B SINK	10/9/2024 05:01	1/22/2025 11:31	70332843037	Lead	<1.0
OHS-042	BOYS LKR DRINKING FOUNTAIN	10/9/2024 04:48	1/22/2025 11:12	70332843027	Lead	<1.0
OHS-043	HALLWAY BOTTLE FILLER	10/9/2024 04:49	1/22/2025 11:14	70332843028	Lead	<1.0
OHS-044	BOYS LKR DRINKING FOUNTAIN	10/9/2024 04:49	1/22/2025 11:15	70332843029	Lead	<1.0
OHS-045	HALLWAY BOTTLE FILLER	10/9/2024 04:38	1/22/2025 10:55	70332843020	Lead	<1.0
OHS-046	BOYS LKR RM DRINKING FOUNTAIN	10/9/2024 04:38	1/22/2025 10:59	70332843021	Lead	<1.0
OHS-047	BOYS LKR RM P DRINKING FOUNTAIN	10/9/2024 04:41	1/22/2025 11:03	70332843023	Lead	<1.0
OHS-048	GIRLS LKR RM POOL DRINKING FOUNTAIN	10/9/2024 04:44	1/22/2025 11:07	70332843024	Lead	<1.0
OHS-049	GIRLS LKR RM POOL DRINKG FOUNTAIN	10/9/2024 04:44	1/22/2025 11:09	70332843025	Lead	<1.0
OHS-050	HALLWAY BOTTLE FILLER	10/9/2024 04:45	1/22/2025 11:11	70332843026	Lead	<1.0
OHS-051	HALLWAY BOTTLE FILLER	10/9/2024 04:38	1/22/2025 11:01	70332843022	Lead	<1.0
OHS-052	GIRLS LKR RM DRINKING FOUNTAIN	10/9/2024 04:37	1/22/2025 10:41	70332843017	Lead	<1.0
OHS-053	HALLWAY BOTTLE FILLER	10/9/2024 04:37	1/22/2025 10:43	70332843018	Lead	<1.0
OHS-058	POOL DRINKING FOUNTAIN	10/9/2024 04:37	1/22/2025 10:50	70332843019	Lead	<1.0
OHS-059	POOL BOTTLE FILLER	10/9/2024 04:36	1/22/2025 10:39	70332843016	Lead	<1.0

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
OHS-061	NURSE OFFICE SINK	10/9/2024 06:10	1/23/2025 10:10	70332843078	Lead	1.1
OHS-076A	KITCHEN SINK	10/9/2024 04:07	1/22/2025 10:12	70332843001	Lead	1.1
OHS-076B	KITCHEN SINK	10/9/2024 04:07	1/22/2025 10:14	70332843002	Lead	12.9
OHS-076C	KITCHEN SINK	10/9/2024 04:08	1/22/2025 10:16	70332843003	Lead	2.9
OHS-078B	Ice Machine	10/9/2024 04:27	1/22/2025 10:38	70332843015	Lead	<1.0
OHS-079	KITCHEN SINK	10/9/2024 04:09	1/22/2025 10:17	70332843004	Lead	<1.0
OHS-080	KITCHEN SINK	10/9/2024 04:10	1/22/2025 10:20	70332843006	Lead	10.8
OHS-082	KITCHEN SINK	10/9/2024 04:11	1/22/2025 10:22	70332843007	Lead	8.0
OHS-083	KITCHEN SINK	10/9/2024 04:09	1/22/2025 10:19	70332843005	Lead	<1.0
OHS-084	KITCHEN SINK	10/9/2024 04:11	1/22/2025 10:24	70332843008	Lead	<1.0
OHS-085	CAFÉ DRINKING FOUNTAIN	10/9/2024 04:22	1/22/2025 10:36	70332843014	Lead	<1.0
OHS-086	CAFÉ DRINKING FOUNTAIN	10/9/2024 04:20	1/22/2025 10:33	70332843012	Lead	<1.0
OHS-087	CAFE BOTTLE FILLER	10/9/2024 04:20	1/22/2025 10:35	70332843013	Lead	<1.0
OHS-090	DISH SINK	10/9/2024 04:16	1/22/2025 10:30	70332843010	Lead	2.1
OHS-091	DISH SINK	10/9/2024 04:12	1/22/2025 10:25	70332843009	Lead	1.2
OHS-092	SERVING LINE SINK	10/9/2024 04:17	1/22/2025 10:31	70332843011	Lead	1.4
OHS-094	FACULTY RM 171 SINK	10/9/2024 05:30	1/22/2025 12:14	70332843054	Lead	2.5
OHS-099	OFFICE RM 171B SINK	10/9/2024 05:27	1/22/2025 12:12	70332843053	Lead	25.5
OHS-104	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:26	1/22/2025 12:10	70332843052	Lead	<1.0
OHS-106	HALLWAY BOTTLE FILLER	10/9/2024 05:32	1/22/2025 12:15	70332843055	Lead	<1.0
OHS-107	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:32	1/22/2025 12:17	70332843056	Lead	<1.0
OHS-204	STORAGE RM 187A SINK	10/9/2024 05:33	1/22/2025 12:18	70332843057	Lead	1.1
OHS-205	STORAGE RM 185A SINK	10/9/2024 05:34	1/22/2025 12:23	70332843058	Lead	6.1
OHS-206	CLASSROOM SINK 187 SINK	10/9/2024 05:36	1/22/2025 12:32	70332843060	Lead	7.0
OHS-210	CLASSROOM SINK 185 SINK	10/9/2024 05:35	1/22/2025 12:28	70332843059	Lead	2.3
OHS-223	CLASSROOM SINK 163 SINK	10/9/2024 05:23	1/22/2025 12:09	70332843051	Lead	7.5
OHS-228	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:21	1/22/2025 12:06	70332843049	Lead	<1.0
OHS-229	HALLWAY BOTTLE FILLER	10/9/2024 05:21	1/22/2025 12:07	70332843050	Lead	<1.0
OHS-233	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:20	1/22/2025 11:59	70332843047	Lead	<1.0
OHS-234	HALLWAY BOTTLE FILLER	10/9/2024 05:20	1/22/2025 12:04	70332843048	Lead	<1.0
OHS-236	HALLWAY BOTTLE FILLER	10/9/2024 05:40	1/22/2025 12:37	70332843061	Lead	<1.0

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results
OHS-237	HALLWAY DRINKING FOUNTAIN	10/9/2024 05:42	1/22/2025 12:41	70332843062	Lead	<1.0
OHS-247	OFFICE RM 66A SINK	10/9/2024 05:44	1/22/2025 12:43	70332843063	Lead	2.4
OHS-256	CLASSROOM SINK 271	10/9/2024 05:46	1/22/2025 12:45	70332843064	Lead	35.5
OHS-257	CLASSROOM SINK 272	10/9/2024 05:48	1/23/2025 09:37	70332843066	Lead	14.3
OHS-258	CLASSROOM SINK 273	10/9/2024 05:47	1/22/2025 12:46	70332843065	Lead	28.7
OHS-259	CLASSROOM SINK 275	10/9/2024 05:51	1/23/2025 09:51	70332843068	Lead	40.2
OHS-260	CLASSROOM SINK 274	10/9/2024 05:48	1/23/2025 09:43	70332843067	Lead	11.3
OHS-262	CLASSROOM SINK 276	10/9/2024 05:53	1/23/2025 09:52	70332843069	Lead	<1.0
OHS-263	ICE MACHINE CLASSROOM SINK 276	10/9/2024 05:57	1/23/2025 10:02	70332843075	Lead	<1.0
OHS-264	CLASSROOM SINK 276	10/9/2024 05:54	1/23/2025 09:57	70332843072	Lead	<1.0
OHS-265	CLASSROOM SINK 276	10/9/2024 05:54	1/23/2025 09:59	70332843073	Lead	<1.0
OHS-266	CLASSROOM SINK 276	10/9/2024 05:54	1/23/2025 10:00	70332843074	Lead	2.0
OHS-267	CLASSROOM SINK 276	10/9/2024 05:53	1/23/2025 09:54	70332843070	Lead	2.3
OHS-268	CLASSROOM SINK 276	10/9/2024 05:53	1/23/2025 09:56	70332843071	Lead	2.0
OHS-269	HALLWAY BOTTLE FILLER	10/9/2024 06:00	1/23/2025 10:03	70332843076	Lead	<1.0
OHS-270	HALLWAY DRINKING FOUNTAIN	10/9/2024 06:00	1/23/2025 10:05	70332843077	Lead	<1.0

NYSDOH Action Level for Lead In Schools of 5 ppb

NYSDOH Action Level	Units
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/



NYSDOH Action Level	Units
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/
5	ug/



January 27, 2025

Pete Colucci  
CiTi BOCES Oswego City School District  
2 Buccaneer Blvd  
Oswego, NY 13126

RE: Project: OSWEGO HIGH SCHOOL 10/9  
Pace Project No.: 70332843

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 14, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen  
michelle.cohen@pacelabs.com  
516-370-6000  
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District  
CiTi BOCES Safety and, CiTi BOCES Oswego City School  
District



## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



## CERTIFICATIONS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

---

### **Pace Analytical Services, LLC - Melville, NY**

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

---

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-076A		Lab ID: 70332843001	Collected: 10/09/24 04:07	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		01/22/25 10:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-076B		Lab ID: 70332843002	Collected: 10/09/24 04:07	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>12.9</b>	ug/L	1.0	1		01/22/25 10:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-076C		Lab ID: 70332843003		Collected: 10/09/24 04:08		Received: 01/14/25 17:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<b>2.9</b>	ug/L	1.0	1		01/22/25 10:16	7439-92-1		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-079</b>								
<b>Lab ID: 70332843004</b>								
Collected: 10/09/24 04:09 Received: 01/14/25 17:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 10:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-083		Lab ID: 70332843005	Collected: 10/09/24 04:09	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-080</b>								
<b>Lab ID: 70332843006</b>								
Collected: 10/09/24 04:10								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>10.8</b>	ug/L	1.0	1		01/22/25 10:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-082		Lab ID: 70332843007	Collected: 10/09/24 04:11	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>8.0</b>	ug/L	1.0	1		01/22/25 10:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-084</b>								
<b>Lab ID: 70332843008</b>								
Collected: 10/09/24 04:11								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 10:24	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-091</b>								
<b>Lab ID: 70332843009</b>								
Collected: 10/09/24 04:12 Received: 01/14/25 17:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.2	ug/L	1.0	1		01/22/25 10:25	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-090</b>								
<b>Lab ID: 70332843010</b>								
Collected: 10/09/24 04:16								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.1	ug/L	1.0	1		01/22/25 10:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-092		Lab ID: 70332843011	Collected: 10/09/24 04:17	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		01/22/25 10:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-086		Lab ID: 70332843012	Collected: 10/09/24 04:20	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-087		Lab ID: 70332843013	Collected: 10/09/24 04:20	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:35	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-085		Lab ID: 70332843014	Collected: 10/09/24 04:22	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:36	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-078B		Lab ID: 70332843015	Collected: 10/09/24 04:27	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-059		Lab ID: 70332843016	Collected: 10/09/24 04:36	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:39	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-052		Lab ID: 70332843017	Collected: 10/09/24 04:37	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-053</b>								
<b>Lab ID: 70332843018</b>								
Collected: 10/09/24 04:37								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 10:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-058		Lab ID: 70332843019	Collected: 10/09/24 04:37	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:50	7439-92-1	M1

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-045		Lab ID: 70332843020	Collected: 10/09/24 04:38	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:55	7439-92-1	M1

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-046		Lab ID: 70332843021	Collected: 10/09/24 04:38	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 10:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-051		Lab ID: 70332843022	Collected: 10/09/24 04:38	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:01	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-047</b>								
<b>Lab ID: 70332843023</b>								
Collected: 10/09/24 04:41								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-048</b>								
<b>Lab ID: 70332843024</b>								
Collected: 10/09/24 04:44								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-049		Lab ID: 70332843025	Collected: 10/09/24 04:44	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-050		Lab ID: 70332843026	Collected: 10/09/24 04:45	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:11	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-042</b>								
<b>Lab ID: 70332843027</b>								
Collected: 10/09/24 04:48								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-043		Lab ID: 70332843028	Collected: 10/09/24 04:49	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-044</b>								
<b>Lab ID: 70332843029</b>								
Collected: 10/09/24 04:49								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-024		Lab ID: 70332843030	Collected: 10/09/24 04:55	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-025		Lab ID: 70332843031	Collected: 10/09/24 04:55	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:19	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-020		Lab ID: 70332843032	Collected: 10/09/24 04:56	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:20	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-021		Lab ID: 70332843033	Collected: 10/09/24 05:56	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:22	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-030		Lab ID: 70332843034	Collected: 10/09/24 05:00	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:27	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-031		Lab ID: 70332843035	Collected: 10/09/24 05:00	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-029		Lab ID: 70332843036	Collected: 10/09/24 05:01	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:30	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-037		Lab ID: 70332843037	Collected: 10/09/24 05:01	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:31	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-033		Lab ID: 70332843038	Collected: 10/09/24 05:03	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:33	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-034</b>								
<b>Lab ID: 70332843039</b>								
Collected: 10/09/24 05:03								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:38	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-008</b>								
<b>Lab ID: 70332843040</b>								
Collected: 10/09/24 05:05 Received: 01/14/25 17:00 Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-009		Lab ID: 70332843041	Collected: 10/09/24 05:05	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:50	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-036</b>								
<b>Lab ID: 70332843042</b>								
Collected: 10/09/24 05:05								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-010		Lab ID: 70332843043	Collected: 10/09/24 05:06	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:53	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-004</b>								
<b>Lab ID: 70332843044</b>								
Collected: 10/09/24 05:09								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.0	ug/L	1.0	1		01/22/25 11:55	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-002</b>								
<b>Lab ID: 70332843045</b>								
Collected: 10/09/24 05:10								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>3.3</b>	ug/L	1.0	1		01/22/25 11:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-019		Lab ID: 70332843046	Collected: 10/09/24 05:12	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 11:58	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-233</b>								
<b>Lab ID: 70332843047</b>								
Collected: 10/09/24 05:20								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 11:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-234</b>								
<b>Lab ID: 70332843048</b>								
Collected: 10/09/24 05:20								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 12:04	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-228</b>								
<b>Lab ID: 70332843049</b>								
Collected: 10/09/24 05:21								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 12:06	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-229		Lab ID: 70332843050	Collected: 10/09/24 05:21	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 12:07	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-223		Lab ID: 70332843051	Collected: 10/09/24 05:23	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.5</b>	ug/L	1.0	1		01/22/25 12:09	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-104</b>								
<b>Lab ID: 70332843052</b>								
Collected: 10/09/24 05:26								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 12:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-099		Lab ID: 70332843053	Collected: 10/09/24 05:27	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>25.5</b>	ug/L	1.0	1		01/22/25 12:12	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-094</b>								
<b>Lab ID: 70332843054</b>								
Collected: 10/09/24 05:30								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.5	ug/L	1.0	1		01/22/25 12:14	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-106		Lab ID: 70332843055	Collected: 10/09/24 05:32	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 12:15	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-107		Lab ID: 70332843056	Collected: 10/09/24 05:32	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 12:17	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-204</b>								
<b>Lab ID: 70332843057</b>								
Collected: 10/09/24 05:33								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.1	ug/L	1.0	1		01/22/25 12:18	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-205		Lab ID: 70332843058	Collected: 10/09/24 05:34	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>6.1</b>	ug/L	1.0	1		01/22/25 12:23	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-210		Lab ID: 70332843059	Collected: 10/09/24 05:35	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.3</b>	ug/L	1.0	1		01/22/25 12:28	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-206		Lab ID: 70332843060	Collected: 10/09/24 05:36	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>7.0</b>	ug/L	1.0	1		01/22/25 12:32	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-236</b>								
<b>Lab ID: 70332843061</b>								
Collected: 10/09/24 05:40								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/22/25 12:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-237		Lab ID: 70332843062	Collected: 10/09/24 05:42	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/22/25 12:41	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-247</b>								
<b>Lab ID: 70332843063</b>								
Collected: 10/09/24 05:44								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.4	ug/L	1.0	1		01/22/25 12:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-256</b>								
<b>Lab ID: 70332843064</b>								
Collected: 10/09/24 05:46								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>35.5</b>	ug/L	1.0	1		01/22/25 12:45	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-258		Lab ID: 70332843065	Collected: 10/09/24 05:47	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>28.7</b>	ug/L	1.0	1		01/22/25 12:46	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-257		Lab ID: 70332843066	Collected: 10/09/24 05:48	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>14.3</b>	ug/L	1.0	1		01/23/25 09:37	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-260		Lab ID: 70332843067	Collected: 10/09/24 05:48	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>11.3</b>	ug/L	1.0	1		01/23/25 09:43	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-259</b>								
<b>Lab ID: 70332843068</b>								
Collected: 10/09/24 05:51								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>40.2</b>	ug/L	1.0	1		01/23/25 09:51	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-262		Lab ID: 70332843069	Collected: 10/09/24 05:53	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 09:52	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-267		Lab ID: 70332843070	Collected: 10/09/24 05:53	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<b>2.3</b>	ug/L	1.0	1		01/23/25 09:54	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-268</b>								
<b>Lab ID: 70332843071</b>								
Collected: 10/09/24 05:53								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.0</b>	ug/L	1.0	1		01/23/25 09:56	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-264</b>								
<b>Lab ID: 70332843072</b>								
Collected: 10/09/24 05:54								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 09:57	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.





### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-265		Lab ID: 70332843073	Collected: 10/09/24 05:54	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 09:59	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-266</b>								
<b>Lab ID: 70332843074</b>								
Collected: 10/09/24 05:54								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<b>2.0</b>	ug/L	1.0	1		01/23/25 10:00	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-263		Lab ID: 70332843075	Collected: 10/09/24 05:57	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 10:02	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-269</b>								
<b>Lab ID: 70332843076</b>								
Collected: 10/09/24 06:00								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 10:03	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>Sample: OHS-270</b>								
<b>Lab ID: 70332843077</b>								
Collected: 10/09/24 06:00								
Received: 01/14/25 17:00								
Matrix: Drinking Water								
<b>200.8 MET ICPMS Drinking Water</b>								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 10:05	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### ANALYTICAL RESULTS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Sample: OHS-061		Lab ID: 70332843078	Collected: 10/09/24 06:10	Received: 01/14/25 17:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
<b>200.8 MET ICPMS Drinking Water</b>		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		01/23/25 10:10	7439-92-1	

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

QC Batch:	381085	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332843001, 70332843002, 70332843003, 70332843004, 70332843005, 70332843006, 70332843007, 70332843008, 70332843009, 70332843010, 70332843011, 70332843012, 70332843013, 70332843014, 70332843015, 70332843016, 70332843017, 70332843018		

METHOD BLANK:	2000038	Matrix:	Water
Associated Lab Samples:	70332843001, 70332843002, 70332843003, 70332843004, 70332843005, 70332843006, 70332843007, 70332843008, 70332843009, 70332843010, 70332843011, 70332843012, 70332843013, 70332843014, 70332843015, 70332843016, 70332843017, 70332843018		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 09:56	

LABORATORY CONTROL SAMPLE:	2000039					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.0	104	85-115	

MATRIX SPIKE SAMPLE:	2000042						
Parameter	Units	70332834001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.1	100	70-130	

MATRIX SPIKE SAMPLE:	2000044						
Parameter	Units	70332834002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	62.3	121	70-130	

SAMPLE DUPLICATE:	2000041					
Parameter	Units	70332834001 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	2000043					
Parameter	Units	70332834002 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	1.8	1.7	3		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

QC Batch:	381086	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332843019, 70332843020, 70332843021, 70332843022, 70332843023, 70332843024, 70332843025, 70332843026, 70332843027, 70332843028, 70332843029, 70332843030, 70332843031, 70332843032, 70332843033, 70332843034, 70332843035, 70332843036, 70332843037, 70332843038		

METHOD BLANK:	2000045	Matrix:	Water
Associated Lab Samples:	70332843019, 70332843020, 70332843021, 70332843022, 70332843023, 70332843024, 70332843025, 70332843026, 70332843027, 70332843028, 70332843029, 70332843030, 70332843031, 70332843032, 70332843033, 70332843034, 70332843035, 70332843036, 70332843037, 70332843038		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 10:44	

LABORATORY CONTROL SAMPLE:	2000046					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.1	100	85-115	

MATRIX SPIKE SAMPLE:	2000048						
Parameter	Units	70332843019 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	72.9	146	70-130	M1

MATRIX SPIKE SAMPLE:	2000050						
Parameter	Units	70332843020 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	66.7	133	70-130	M1

SAMPLE DUPLICATE:	2000047					
Parameter	Units	70332843019 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	2000049					
Parameter	Units	70332843020 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.





### QUALITY CONTROL DATA

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

QC Batch:	381087	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332843039, 70332843040, 70332843041, 70332843042, 70332843043, 70332843044, 70332843045, 70332843046, 70332843047, 70332843048, 70332843049, 70332843050, 70332843051, 70332843052, 70332843053, 70332843054, 70332843055, 70332843056, 70332843057, 70332843058		

METHOD BLANK:	2000051	Matrix:	Water
Associated Lab Samples:	70332843039, 70332843040, 70332843041, 70332843042, 70332843043, 70332843044, 70332843045, 70332843046, 70332843047, 70332843048, 70332843049, 70332843050, 70332843051, 70332843052, 70332843053, 70332843054, 70332843055, 70332843056, 70332843057, 70332843058		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 11:35	

LABORATORY CONTROL SAMPLE:	2000052					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	52.2	104	85-115	

MATRIX SPIKE SAMPLE:	2000054						
Parameter	Units	70332843039 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.4	99	70-130	

MATRIX SPIKE SAMPLE:	2000056						
Parameter	Units	70332843040 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	49.5	99	70-130	

SAMPLE DUPLICATE:	2000053					
Parameter	Units	70332843039 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	2000055					
Parameter	Units	70332843040 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

QC Batch:	381106	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332843059, 70332843060, 70332843061, 70332843062, 70332843063, 70332843064, 70332843065		

METHOD BLANK:	2000133	Matrix:	Water
Associated Lab Samples:	70332843059, 70332843060, 70332843061, 70332843062, 70332843063, 70332843064, 70332843065		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/22/25 12:25	

LABORATORY CONTROL SAMPLE: 2000134						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.1	100	85-115	

MATRIX SPIKE SAMPLE: 2000136							
Parameter	Units	70332843059 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		2.3	50	59.8	115	70-130

MATRIX SPIKE SAMPLE: 2000138							
Parameter	Units	70332843060 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		7.0	50	61.8	110	70-130

SAMPLE DUPLICATE: 2000135					
Parameter	Units	70332843059 Result	Dup Result	RPD	Qualifiers
Lead	ug/L		2.3	2.3	0

SAMPLE DUPLICATE: 2000137					
Parameter	Units	70332843060 Result	Dup Result	RPD	Qualifiers
Lead	ug/L		7.0	6.9	2

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA**

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

QC Batch:	381271	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332843066, 70332843067, 70332843068, 70332843069, 70332843070, 70332843071, 70332843072, 70332843073, 70332843074, 70332843075, 70332843076, 70332843077, 70332843078		

METHOD BLANK:	2001296	Matrix:	Water
Associated Lab Samples:	70332843066, 70332843067, 70332843068, 70332843069, 70332843070, 70332843071, 70332843072, 70332843073, 70332843074, 70332843075, 70332843076, 70332843077, 70332843078		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/23/25 09:34	

LABORATORY CONTROL SAMPLE: 2001297						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE: 2001300							
Parameter	Units	70332843066 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	14.3	50	61.9	95	70-130	

MATRIX SPIKE SAMPLE: 2001302							
Parameter	Units	70332843067 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	11.3	50	59.9	97	70-130	

SAMPLE DUPLICATE: 2001299					
Parameter	Units	70332843066 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	14.3	13.6	5	

SAMPLE DUPLICATE: 2001301					
Parameter	Units	70332843067 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	11.3	11.1	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



## QUALIFIERS

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

---

### DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

### ANALYTE QUALIFIERS

M1 Matrix spike recovery exceeded QC limits. Batch accepted based on laboratory control sample (LCS) recovery.

## REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,  
without the written consent of Pace Analytical Services, LLC.



### QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: OSWEGO HIGH SCHOOL 10/9

Pace Project No.: 70332843

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332843001	OHS-076A	EPA 200.8	381085		
70332843002	OHS-076B	EPA 200.8	381085		
70332843003	OHS-076C	EPA 200.8	381085		
70332843004	OHS-079	EPA 200.8	381085		
70332843005	OHS-083	EPA 200.8	381085		
70332843006	OHS-080	EPA 200.8	381085		
70332843007	OHS-082	EPA 200.8	381085		
70332843008	OHS-084	EPA 200.8	381085		
70332843009	OHS-091	EPA 200.8	381085		
70332843010	OHS-090	EPA 200.8	381085		
70332843011	OHS-092	EPA 200.8	381085		
70332843012	OHS-086	EPA 200.8	381085		
70332843013	OHS-087	EPA 200.8	381085		
70332843014	OHS-085	EPA 200.8	381085		
70332843015	OHS-078B	EPA 200.8	381085		
70332843016	OHS-059	EPA 200.8	381085		
70332843017	OHS-052	EPA 200.8	381085		
70332843018	OHS-053	EPA 200.8	381085		
70332843019	OHS-058	EPA 200.8	381086		
70332843020	OHS-045	EPA 200.8	381086		
70332843021	OHS-046	EPA 200.8	381086		
70332843022	OHS-051	EPA 200.8	381086		
70332843023	OHS-047	EPA 200.8	381086		
70332843024	OHS-048	EPA 200.8	381086		
70332843025	OHS-049	EPA 200.8	381086		
70332843026	OHS-050	EPA 200.8	381086		
70332843027	OHS-042	EPA 200.8	381086		
70332843028	OHS-043	EPA 200.8	381086		
70332843029	OHS-044	EPA 200.8	381086		
70332843030	OHS-024	EPA 200.8	381086		
70332843031	OHS-025	EPA 200.8	381086		
70332843032	OHS-020	EPA 200.8	381086		
70332843033	OHS-021	EPA 200.8	381086		
70332843034	OHS-030	EPA 200.8	381086		
70332843035	OHS-031	EPA 200.8	381086		
70332843036	OHS-029	EPA 200.8	381086		
70332843037	OHS-037	EPA 200.8	381086		
70332843038	OHS-033	EPA 200.8	381086		
70332843039	OHS-034	EPA 200.8	381087		
70332843040	OHS-008	EPA 200.8	381087		
70332843041	OHS-009	EPA 200.8	381087		
70332843042	OHS-036	EPA 200.8	381087		
70332843043	OHS-010	EPA 200.8	381087		
70332843044	OHS-004	EPA 200.8	381087		
70332843045	OHS-002	EPA 200.8	381087		
70332843046	OHS-019	EPA 200.8	381087		
70332843047	OHS-233	EPA 200.8	381087		
70332843048	OHS-234	EPA 200.8	381087		

### REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



**QUALITY CONTROL DATA CROSS REFERENCE TABLE**

Project: OSWEGO HIGH SCHOOL 10/9  
 Pace Project No.: 70332843

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332843049	OHS-228	EPA 200.8	381087		
70332843050	OHS-229	EPA 200.8	381087		
70332843051	OHS-223	EPA 200.8	381087		
70332843052	OHS-104	EPA 200.8	381087		
70332843053	OHS-099	EPA 200.8	381087		
70332843054	OHS-094	EPA 200.8	381087		
70332843055	OHS-106	EPA 200.8	381087		
70332843056	OHS-107	EPA 200.8	381087		
70332843057	OHS-204	EPA 200.8	381087		
70332843058	OHS-205	EPA 200.8	381087		
70332843059	OHS-210	EPA 200.8	381106		
70332843060	OHS-206	EPA 200.8	381106		
70332843061	OHS-236	EPA 200.8	381106		
70332843062	OHS-237	EPA 200.8	381106		
70332843063	OHS-247	EPA 200.8	381106		
70332843064	OHS-256	EPA 200.8	381106		
70332843065	OHS-258	EPA 200.8	381106		
70332843066	OHS-257	EPA 200.8	381271		
70332843067	OHS-260	EPA 200.8	381271		
70332843068	OHS-259	EPA 200.8	381271		
70332843069	OHS-262	EPA 200.8	381271		
70332843070	OHS-267	EPA 200.8	381271		
70332843071	OHS-268	EPA 200.8	381271		
70332843072	OHS-264	EPA 200.8	381271		
70332843073	OHS-265	EPA 200.8	381271		
70332843074	OHS-266	EPA 200.8	381271		
70332843075	OHS-263	EPA 200.8	381271		
70332843076	OHS-269	EPA 200.8	381271		
70332843077	OHS-270	EPA 200.8	381271		
70332843078	OHS-061	EPA 200.8	381271		

**REPORT OF LABORATORY ANALYSIS**

This report shall not be reproduced, except in full,  
 without the written consent of Pace Analytical Services, LLC.



**CHAIN-OF-CUSTODY / ANALYSIS**  
The Chain-of-Custody is a LEGAL DOCUMENT  
Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions

WO#: 70332843



1 of 7

**Section A**  
Company: Oswego City School District  
Address: 2 Buccaneer Blvd, Oswego NY 13126  
Email: [Pcolucci2@oswego.org](mailto:Pcolucci2@oswego.org) Fax: [ ]  
Requested Due Date: [ ]

**Section B**  
Report To: Ian Rowberry (irowberry@oswego.org)  
Copy To: Alisha Hartford (ahartford@citiboces.org)  
Purchase Order #: [ ]  
Project Name: Oswego High School  
Project #: [ ]

**Section C**  
Invoice Information:  
Attention: Pete Colucci  
Company Name: Oswego City School District  
Address: 2 Buccaneer Blvd, Oswego NY 13126  
Pace Quote: [ ]  
Pace Project Manager: alexandria.correa@pacelabs.com  
Pace Profile #: [ ]

Regulatory Agency: [ ]  
State / Location: NY

ITEM #	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	PRESERVATIVES		ANALYSES TEST	Y/N	Requested Analysis Filtered (Y/N)	TEMP in C	Received on	Ice (Y/N)	Custody Sealed (Y/N)	Samples Intact (Y/N)
		START DATE TIME	END DATE TIME				H2SO4	HCl								
1	DWG	10/9	0407				X									
2	DWG	10/9	0407				X									
3	DWG	10/9	0408				X									
4	DWG	10/9	0409				X									
5	DWG	10/9	0409				X									
6	DWG	10/9	0410				X									
7	DWG	10/9	0411				X									
8	DWG	10/9	0411				X									
9	DWG	10/9	0412				X									
10	DWG	10/9	0416				X									
11	DWG	10/9	0417				X									
12	DWG	10/9	0420				X									

**ADDITIONAL COMMENTS**

RELINQUISHED BY / AFFILIATION: Jim Patroch  
DATE: 10/8  
TIME: 12P

ACCEPTED BY / AFFILIATION: Jim Patroch  
DATE: 11/14  
TIME: 12P

DATE SIGNED: [Signature]

SAMPLER NAME AND SIGNATURE: AEB Pace LZ  
DATE SIGNED: 11/15/25 600

PRINT Name of SAMPLER: Alisha Hartford  
SIGNATURE of SAMPLER: [Signature]

DATE SIGNED: [Signature]

RESIDUAL CHLORINE (Y/N): [ ]









# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately. Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at <https://info.pacelabs.com/hubs/pas-standard-terms.pdf>.

### Section A

**Required Client Information:**  
 Company: Oswego City School District  
 Address: 2 Buccaneer Blvd, Oswego NY 13126  
 Email: [Pcolucci2@oswego.org](mailto:Pcolucci2@oswego.org)  
 Phone: 315-341-2906 Fax  
 Requested Due Date:

**Required Project Information:**  
 Report To: Ian Rowberry (irowberry@oswego.org)  
 Copy To: Aleisha Hartford (ahartford@citiboces.org)  
[safelyandrisk@citiboces.org](mailto:safelyandrisk@citiboces.org)  
 Purchase Order #:   
 Project Name: OHS-Oswego High School - OHS  
 Project #:

**Invoice Information:**  
 Attention: Pete Colucci  
 Company Name: Oswego City School District  
 Address: 2 Buccaneer Blvd, Oswego NY 13126  
 Pace Quote:  
 Pace Project Manager: [alexandria.correa@pacelabs.com](mailto:alexandria.correa@pacelabs.com)  
 Pace Profile #:

**Regulatory Agency**  
 State / Location  
 NY

### Section B

ITEM #	MATRIX	CODE	COLLECTED		SAMPLE TYPE (G-GRAB C-COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES							ANALYSES TEST Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)
			START DATE	START TIME				END DATE	END TIME	Unpreserved	H2SO4	HNO3	HCl	NaOH			
37	Drinking Water	DW	10/9	0501	DWG	DWG		X									
38	Water	WT	10/9	0503	DWG	DWG		X									
39	Waste Water	WW	10/9	0503	DWG	DWG		X									
40	Product	P	10/9	0505	DWG	DWG		X									
41	Soil/Solid	SL	10/9	0505	DWG	DWG		X									
42	Oil	OL	10/9	0505	DWG	DWG		X									
43	Wipe	WP	10/9	0505	DWG	DWG		X									
44	Air	AR	10/9	0505	DWG	DWG		X									
45	Other	OT	10/9	0505	DWG	DWG		X									
46	Tissue	TS	10/9	0505	DWG	DWG		X									
47			10/9	0520	DWG	DWG		X									
48			10/9	0520	DWG	DWG		X									

### Section C

**Additional Comments:**

RELINQUISHED BY / AFFILIATION: Aleisha Hartford  
 DATE: 10/8  
 TIME: 12P

ACCEPTED BY / AFFILIATION: Bimfabrick  
 DATE: 1/14  
 TIME: 1215

DATE SIGNED: AEB  
 DATE SIGNED: 1/5/25  
 TIME: 600

TEMP in C

Received on Ice (Y/N)

Custody Sealed (Y/N)

Cooler (Y/N)

Samples Intact (Y/N)









Effective Date:

WO#: 70332843

Client Name: Oswego City CS

Project #

PM: MC1 Due Date: 01/24/25

CLIENT: OswegoCityCS

Courier: Fed Ex UPS USPS Client Commercial Pac Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziplo Non Other Type of Ice: Wet Blue None

Thermometer Used: Thru Correction Factor: h.o.d Samples on ice, cooling process has begun

Cooler Temperature(C): 16.7 Cooler Temperature Corrected(C): 16.7 Date/Time 5035A kits placed in freezer

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork

Date and Initials of person examining contents: 1/15/25

Table with 2 columns: Question/Status and Comments. Rows include Chain of Custody Present, Filled Out, Relinquished, Sampler Name & Signature on COC, Samples Arrived within Hold Time, Short Hold Time Analysis, Rush Turn Around Time Requested, Sufficient Volume, Correct Containers Used, Containers Intact, Filtered volume received for Dissolved tests, Sample Labels match COC.

Date and Initials of person checking preservation: 1/15/25

Table with 2 columns: Question/Status and Comments. Rows include All containers needing preservation have been, pH paper Lot #, All containers needing preservation are found to be in compliance with method recommendation, Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water), Per Method, VOA pH is checked after analysis, Samples checked for dechlorination, KI starch test strips Lot #, Residual chlorine strips Lot #, SM 4500 CN samples checked for sul, Lead Acetate Strips Lot #, Headspace in ALK Bottle (>6mm), Headspace in VOA Vials (>6mm), Trip Blank Present, Trip Blank Custody Seals Present.

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

\* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.