

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level	Units
OMS 002	WORK RM 101H SINK	10/8/2024 04:20	1/23/2025 12:34	70332847001	Lead	2.6	5	ug/L
OMS 003	NURSE OFFICE 102A SINK	10/8/2024 04:29	1/23/2025 12:39	70332847002	Lead	9.9	5	ug/L
OMS 005	NURSE 102 SINK	10/8/2024 04:28	1/23/2025 12:40	70332847003	Lead	1.1	5	ug/L
OMS 006	HALLWAY BOTTLE FILLER	10/8/2024 04:32	1/23/2025 12:42	70332847004	Lead	<1.0	5	ug/L
OMS 007	HALLWAY DRINKING FOUNTAIN	10/8/2024 04:32	1/23/2025 12:43	70332847005	Lead	<1.0	5	ug/L
OMS 010	CLASSROOM 117 SINK	10/8/2024 04:34	1/23/2025 12:45	70332847006	Lead	7.4	5	ug/L
OMS 012	STORAGE RM 123A SINK	10/8/2024 04:36	1/23/2025 12:46	70332847007	Lead	16.6	5	ug/L
OMS 015	RESOURCE RM 123 SINK	10/8/2024 04:37	1/23/2025 12:51	70332847008	Lead	31.3	5	ug/L
OMS 016	CLASSROOM 124 SINK	10/8/2024 04:39	1/23/2025 12:58	70332847009	Lead	<1.0	5	ug/L
OMS 017	CLASSROOM 124 SINK	10/8/2024 04:38	1/23/2025 13:03	70332847010	Lead	<1.0	5	ug/L
OMS 018	CLASSROOM 124SINK	10/8/2024 04:39	1/23/2025 13:05	70332847011	Lead	<1.0	5	ug/L
OMS 019	CLASSROOM 124 SINK	10/8/2024 04:39	1/23/2025 13:06	70332847012	Lead	<1.0	5	ug/L
OMS 021	HALLWAY DRINKING FOUNTAIN	10/8/2024 04:42	1/23/2025 13:08	70332847013	Lead	<1.0	5	ug/L
OMS 023	CLASSROOM 151 SINK	10/8/2024 04:45	1/23/2025 13:09	70332847014	Lead	<1.0	5	ug/L
OMS 026	HALLWAY DRINKING FOUNTAIN	10/8/2024 04:45	1/23/2025 13:11	70332847015	Lead	<1.0	5	ug/L
OMS 027	HALLWAY BOTTLE FILLER	10/8/2024 04:46	1/23/2025 13:16	70332847016	Lead	<1.0	5	ug/L
OMS 032	STORAGE RM 141B SINK	10/8/2024 04:51	1/23/2025 13:17	70332847017	Lead	3.3	5	ug/L
OMS 035	CAFÉ SINK	10/8/2024 04:53	1/23/2025 13:19	70332847018	Lead	<1.0	5	ug/L
OMS 036	KITCHEN SINK	10/8/2024 05:08	1/23/2025 13:30	70332847025	Lead	<1.0	5	ug/L
OMS 037	KITCHEN SINK	10/8/2024 05:20	1/23/2025 13:45	70332847029	Lead	<1.0	5	ug/L
OMS 038	KITCHEN SINK	10/8/2024 05:02	1/23/2025 13:27	70332847023	Lead	<1.0	5	ug/L
OMS 039	KITCHEN SINK	10/8/2024 05:04	1/23/2025 13:28	70332847024	Lead	2.1	5	ug/L
OMS 041	KITCHEN SINK	10/8/2024 04:58	1/23/2025 13:25	70332847022	Lead	<1.0	5	ug/L
OMS 042	KITCHEN SINK	10/8/2024 04:57	1/23/2025 13:23	70332847021	Lead	<1.0	5	ug/L
OMS 043	KITCHEN SINK	10/8/2024 04:56	1/23/2025 13:22	70332847020	Lead	1.3	5	ug/L
OMS 044	KETTLE FILLER	10/8/2024 05:19	1/23/2025 13:36	70332847027	Lead	33.7	5	ug/L
OMS 045	KETTLE FILLER	10/8/2024 05:17	1/23/2025 13:34	70332847026	Lead	9.5	5	ug/L
OMS 048	KITCHEN SINK	10/8/2024 04:55	1/23/2025 13:20	70332847019	Lead	<1.0	5	ug/L
OMS 048A	KITCHEN SINK	10/8/2024 04:59	1/23/2025 13:57	70332847033	Lead	<1.0	5	ug/L
OMS 048B	KITCHEN SINK	10/8/2024 04:59	1/23/2025 13:56	70332847032	Lead	1.7	5	ug/L
OMS 050	POT FILLER	10/8/2024 05:23	1/23/2025 13:53	70332847030	Lead	1.4	5	ug/L
OMS 051	POT FILLER	10/8/2024 05:24	1/23/2025 13:54	70332847031	Lead	8.8	5	ug/L
OMS 072	HALLWAY DRINKING FOUNTAIN	10/8/2024 05:39	1/23/2025 13:59	70332847034	Lead	<1.0	5	ug/L
OMS 073	CLASSROOM 107 SINK	10/8/2024 05:38	1/23/2025 14:02	70332847036	Lead	2.2	5	ug/L
OMS 077	UPPER GYM DRINKING FOUNTAIN	10/8/2024 05:33	1/23/2025 14:01	70332847035	Lead	<1.0	5	ug/L
OMS 080	CLASSROOM 43 SINK	10/8/2024 05:54	1/23/2025 14:21	70332847046	Lead	<1.0	5	ug/L
OMS 081	CLASSROOM 29 SINK	10/8/2024 05:53	1/23/2025 14:16	70332847043	Lead	2.2	5	ug/L
OMS 082	CLASSROOM 29 SINK	10/8/2024 05:52	1/23/2025 14:15	70332847042	Lead	3.4	5	ug/L

OMS 083	HALLWAY BOTTLE FILLER	10/8/2024 05:55	1/23/2025 14:18	70332847044	Lead	<1.0	5	ug/L
OMS 084	HALLWAY DRINKING FOUNTAIN	10/8/2024 05:54	1/23/2025 14:20	70332847045	Lead	<1.0	5	ug/L
OMS 089	HALLWAY DRINKING FOUNTAIN	10/8/2024 05:42	1/23/2025 14:04	70332847037	Lead	<1.0	5	ug/L
OMS 090	HALLWAY BOTTLE FILLER	10/8/2024 05:42	1/23/2025 14:05	70332847038	Lead	<1.0	5	ug/L
OMS 095	FACULTY RM 9 SINK	10/8/2024 05:45	1/23/2025 14:07	70332847039	Lead	<1.0	5	ug/L
OMS 097	CUSTODIAN RM SINK	10/8/2024 05:46	1/23/2025 14:12	70332847040	Lead	4.9	5	ug/L
OMS 105	HALLWAY DRINKING FOUNTAIN	10/8/2024 05:59	1/23/2025 14:23	70332847047	Lead	<1.0	5	ug/L
OMS 110	KITCHEN ICE MACHINE	10/8/2024 05:19	1/23/2025 13:41	70332847028	Lead	<1.0	5	ug/L
OMS MAIN 111	SPIGOT OFF MAIN	10/8/2024 05:46	1/23/2025 14:13	70332847041	Lead	1.8	5	ug/L

NYSDOH Action Level for Lead In Schools of 5 ppb



January 27, 2025

Pete Colucci
CiTi BOCES Oswego City School District
2 Buccaneer Blvd
Oswego, NY 13126

RE: Project: OSWEGO MIDDLE SCHOOL 10/8
Pace Project No.: 70332847

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Michelle Cohen
michelle.cohen@pacelabs.com
516-370-6000
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District
CiTi BOCES Safety and, CiTi BOCES Oswego City School
District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 002		Lab ID: 70332847001	Collected: 10/08/24 04:20	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.6	ug/L	1.0	1		01/23/25 12:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 003		Lab ID: 70332847002	Collected: 10/08/24 04:29	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.9	ug/L	1.0	1		01/23/25 12:39	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 005		Lab ID: 70332847003		Collected: 10/08/24 04:28	Received: 01/15/25 06:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		01/23/25 12:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 006								
Lab ID: 70332847004								
Collected: 10/08/24 04:32 Received: 01/15/25 06:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 12:42	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 007								
Lab ID: 70332847005								
Collected: 10/08/24 04:32								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 12:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 010		Lab ID: 70332847006	Collected: 10/08/24 04:34	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.4	ug/L	1.0	1		01/23/25 12:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 012		Lab ID: 70332847007	Collected: 10/08/24 04:36	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	16.6	ug/L	1.0	1		01/23/25 12:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 015								
Lab ID: 70332847008								
Collected: 10/08/24 04:37								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	31.3	ug/L	1.0	1		01/23/25 12:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 016		Lab ID: 70332847009	Collected: 10/08/24 04:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 12:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 017								
Lab ID: 70332847010								
Collected: 10/08/24 04:38								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 018		Lab ID: 70332847011	Collected: 10/08/24 04:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 019		Lab ID: 70332847012	Collected: 10/08/24 04:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 021								
Lab ID: 70332847013								
Collected: 10/08/24 04:42								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 023		Lab ID: 70332847014	Collected: 10/08/24 04:45	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 026								
Lab ID: 70332847015								
Collected: 10/08/24 04:45								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 027								
Lab ID: 70332847016								
Collected: 10/08/24 04:46								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 032								
Lab ID: 70332847017								
Collected: 10/08/24 04:51								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.3	ug/L	1.0	1		01/23/25 13:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 035								
Lab ID: 70332847018								
Collected: 10/08/24 04:53								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:19	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 048								
Lab ID: 70332847019								
Collected: 10/08/24 04:55								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 043								
Lab ID: 70332847020								
Collected: 10/08/24 04:56								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.3	ug/L	1.0	1		01/23/25 13:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 042								
Lab ID: 70332847021								
Collected: 10/08/24 04:57								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 041								
Lab ID: 70332847022								
Collected: 10/08/24 04:58								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 038								
Lab ID: 70332847023								
Collected: 10/08/24 05:02								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 13:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 039		Lab ID: 70332847024	Collected: 10/08/24 05:04	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		01/23/25 13:28	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 036		Lab ID: 70332847025	Collected: 10/08/24 05:08	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 045								
Lab ID: 70332847026								
Collected: 10/08/24 05:17								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	9.5	ug/L	1.0	1		01/23/25 13:34	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 044		Lab ID: 70332847027	Collected: 10/08/24 05:19	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	33.7	ug/L	1.0	1		01/23/25 13:36	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 110		Lab ID: 70332847028	Collected: 10/08/24 05:19	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 037		Lab ID: 70332847029	Collected: 10/08/24 05:20	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:45	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 050								
Lab ID: 70332847030								
Collected: 10/08/24 05:23 Received: 01/15/25 06:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.4	ug/L	1.0	1		01/23/25 13:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 051		Lab ID: 70332847031	Collected: 10/08/24 05:24	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.8	ug/L	1.0	1		01/23/25 13:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 048B		Lab ID: 70332847032		Collected: 10/08/24 04:59	Received: 01/15/25 06:00	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.7	ug/L	1.0	1		01/23/25 13:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 048A		Lab ID: 70332847033	Collected: 10/08/24 04:59	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 072		Lab ID: 70332847034	Collected: 10/08/24 05:39	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 13:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 077								
Lab ID: 70332847035								
Collected: 10/08/24 05:33								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 073		Lab ID: 70332847036	Collected: 10/08/24 05:38	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.2	ug/L	1.0	1		01/23/25 14:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 089								
Lab ID: 70332847037								
Collected: 10/08/24 05:42								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 090								
Lab ID: 70332847038								
Collected: 10/08/24 05:42								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 095		Lab ID: 70332847039	Collected: 10/08/24 05:45	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 14:07	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 097								
Lab ID: 70332847040								
Collected: 10/08/24 05:46 Received: 01/15/25 06:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	4.9	ug/L	1.0	1		01/23/25 14:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS MAIN 111								
Lab ID: 70332847041								
Collected: 10/08/24 05:46								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	1.8	ug/L	1.0	1		01/23/25 14:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 082								
Lab ID: 70332847042								
Collected: 10/08/24 05:52								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	3.4	ug/L	1.0	1		01/23/25 14:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 081								
Lab ID: 70332847043								
Collected: 10/08/24 05:53								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.2	ug/L	1.0	1		01/23/25 14:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Sample: OMS 083		Lab ID: 70332847044	Collected: 10/08/24 05:55	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/23/25 14:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 084								
Lab ID: 70332847045								
Collected: 10/08/24 05:54								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 080								
Lab ID: 70332847046								
Collected: 10/08/24 05:54								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:21	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: OMS 105								
Lab ID: 70332847047								
Collected: 10/08/24 05:59								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/23/25 14:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

QC Batch:	381283	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332847001, 70332847002, 70332847003, 70332847004, 70332847005, 70332847006, 70332847007		

METHOD BLANK:	2001379	Matrix:	Water
Associated Lab Samples:	70332847001, 70332847002, 70332847003, 70332847004, 70332847005, 70332847006, 70332847007		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/23/25 12:02	

LABORATORY CONTROL SAMPLE: 2001380						
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.1	102	85-115	

MATRIX SPIKE SAMPLE: 2001382							
Parameter	Units	70332883049 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	53.3	103	70-130	

MATRIX SPIKE SAMPLE: 2001384							
Parameter	Units	70332883050 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	46.3	50	89.2	86	70-130	

SAMPLE DUPLICATE: 2001381					
Parameter	Units	70332883049 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.7	3	

SAMPLE DUPLICATE: 2001383					
Parameter	Units	70332883050 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	46.3	46.5	0	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

QC Batch:	381285	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70332847008, 70332847009, 70332847010, 70332847011, 70332847012, 70332847013, 70332847014, 70332847015, 70332847016, 70332847017, 70332847018, 70332847019, 70332847020, 70332847021, 70332847022, 70332847023, 70332847024, 70332847025, 70332847026, 70332847027		

METHOD BLANK:	2001385	Matrix:	Water
Associated Lab Samples:	70332847008, 70332847009, 70332847010, 70332847011, 70332847012, 70332847013, 70332847014, 70332847015, 70332847016, 70332847017, 70332847018, 70332847019, 70332847020, 70332847021, 70332847022, 70332847023, 70332847024, 70332847025, 70332847026, 70332847027		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/23/25 12:48	

LABORATORY CONTROL SAMPLE:	2001386					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.9	102	85-115	

MATRIX SPIKE SAMPLE:	2001388						
Parameter	Units	70332847008 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	31.3	50	78.6	95	70-130	

MATRIX SPIKE SAMPLE:	2001390						
Parameter	Units	70332847009 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.8	101	70-130	

SAMPLE DUPLICATE:	2001387					
Parameter	Units	70332847008 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	31.3	30.6	2		

SAMPLE DUPLICATE:	2001389					
Parameter	Units	70332847009 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

QC Batch: 381287

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70332847028, 70332847029, 70332847030, 70332847031, 70332847032, 70332847033, 70332847034, 70332847035, 70332847036, 70332847037, 70332847038, 70332847039, 70332847040, 70332847041, 70332847042, 70332847043, 70332847044, 70332847045, 70332847046, 70332847047

METHOD BLANK: 2001394

Matrix: Water

Associated Lab Samples: 70332847028, 70332847029, 70332847030, 70332847031, 70332847032, 70332847033, 70332847034, 70332847035, 70332847036, 70332847037, 70332847038, 70332847039, 70332847040, 70332847041, 70332847042, 70332847043, 70332847044, 70332847045, 70332847046, 70332847047

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/23/25 13:37	

LABORATORY CONTROL SAMPLE: 2001395

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.2	100	85-115	

MATRIX SPIKE SAMPLE: 2001397

Parameter	Units	70332847028 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	56.4	113	70-130	

MATRIX SPIKE SAMPLE: 2001399

Parameter	Units	70332847029 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.1	102	70-130	

SAMPLE DUPLICATE: 2001396

Parameter	Units	70332847028 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2001398

Parameter	Units	70332847029 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: OSWEGO MIDDLE SCHOOL 10/8

Pace Project No.: 70332847

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332847001	OMS 002	EPA 200.8	381283		
70332847002	OMS 003	EPA 200.8	381283		
70332847003	OMS 005	EPA 200.8	381283		
70332847004	OMS 006	EPA 200.8	381283		
70332847005	OMS 007	EPA 200.8	381283		
70332847006	OMS 010	EPA 200.8	381283		
70332847007	OMS 012	EPA 200.8	381283		
70332847008	OMS 015	EPA 200.8	381285		
70332847009	OMS 016	EPA 200.8	381285		
70332847010	OMS 017	EPA 200.8	381285		
70332847011	OMS 018	EPA 200.8	381285		
70332847012	OMS 019	EPA 200.8	381285		
70332847013	OMS 021	EPA 200.8	381285		
70332847014	OMS 023	EPA 200.8	381285		
70332847015	OMS 026	EPA 200.8	381285		
70332847016	OMS 027	EPA 200.8	381285		
70332847017	OMS 032	EPA 200.8	381285		
70332847018	OMS 035	EPA 200.8	381285		
70332847019	OMS 048	EPA 200.8	381285		
70332847020	OMS 043	EPA 200.8	381285		
70332847021	OMS 042	EPA 200.8	381285		
70332847022	OMS 041	EPA 200.8	381285		
70332847023	OMS 038	EPA 200.8	381285		
70332847024	OMS 039	EPA 200.8	381285		
70332847025	OMS 036	EPA 200.8	381285		
70332847026	OMS 045	EPA 200.8	381285		
70332847027	OMS 044	EPA 200.8	381285		
70332847028	OMS 110	EPA 200.8	381287		
70332847029	OMS 037	EPA 200.8	381287		
70332847030	OMS 050	EPA 200.8	381287		
70332847031	OMS 051	EPA 200.8	381287		
70332847032	OMS 048B	EPA 200.8	381287		
70332847033	OMS 048A	EPA 200.8	381287		
70332847034	OMS 072	EPA 200.8	381287		
70332847035	OMS 077	EPA 200.8	381287		
70332847036	OMS 073	EPA 200.8	381287		
70332847037	OMS 089	EPA 200.8	381287		
70332847038	OMS 090	EPA 200.8	381287		
70332847039	OMS 095	EPA 200.8	381287		
70332847040	OMS 097	EPA 200.8	381287		
70332847041	OMS MAIN 111	EPA 200.8	381287		
70332847042	OMS 082	EPA 200.8	381287		
70332847043	OMS 081	EPA 200.8	381287		
70332847044	OMS 083	EPA 200.8	381287		
70332847045	OMS 084	EPA 200.8	381287		
70332847046	OMS 080	EPA 200.8	381287		
70332847047	OMS 105	EPA 200.8	381287		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



WO#: 70332847

CHAIN-OF-CUSTODY

The Chain-of-Custody is a LEGAL

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Term

Section A

Required Client Information:

Company: Oswego City School District
Address: 2 Buccaneer Blvd, Oswego NY 13126
Email: Pcolucc2@oswego.org
Phone: 315-341-2806 Fax

Section B

Required Project Information:

Report To: Ian Rowberry (rowberry@oswego.org)
Copy To: Aleisha Hartford (ahartford@citiboces.org)
Purchase Order #:
Project Name: Oswego Middle School

Section C

Invoice Information:

Attention: Pete Colucci
Company Name: Oswego City School District
Address: 2 Buccaneer Blvd, Oswego NY 13126
Pace Quote:
Pace Project Manager: alexandria.correa@paceabs.com

Terms.pdf.

Page: 1 Of 4

Form with fields for Regulatory Agency, State/Location, and Project Profile #.

Main data table with columns: ITEM #, MATRIX, SAMPLE ID, MATRIX CODE, SAMPLE TYPE, COLLECTED (START/END DATE/TIME), RELINQUISHED BY/AFFILIATION, DATE, TIME, ACCEPTED BY/AFFILIATION, DATE, TIME, ANALYSES TEST, PRESERVATIVES, LEAD BY 200.8, Residual Chlorine (Y/N), and SAMPLE CONDITIONS.

Summary section including ADDITIONAL COMMENTS, SAMPLER NAME AND SIGNATURE, and RECEIVED ON.



CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace Terms and Conditions found at <https://info.pacelabs.com/hubfs/pas-standard-terms.pdf>.

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company:	Oswego City School District	Report To:	Ian Rowberry (irowber@oswego.org)	Attention:	Pete Colucci
Address:	2 Buccaneer Blvd, Oswego NY 13126	Copy To:	Aleisha Hartford (ahartford@cliboces.org)	Company Name:	Oswego City School District
Email:	Pcolucc2@oswego.org	Project Name:	0MS	Address:	2 Buccaneer Blvd, Oswego NY 13126
Phone:	315-341-2906	Purchase Order #:		Pace Quote:	
Requested Due Date:				Pace Project Manager:	alexandria.correa@pacelabs.com
				Pace Profile #:	
				Regulatory Agency:	
				State / Location:	NY

ITEM #	MATRIX	CODE	SAMPLE TYPE (G-GRAB C-COMP)	COLLECTED		DATE	TIME	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	TEMP in C	Received on	Ice (Y/N)	Custody (Y/N)	Sealed (Y/N)	Cooler (Y/N)	Samples Intact (Y/N)	
				START	END															
25	Drinking Water	DW	DWG	10/18/24	0508															
26	Waste Water	WW	DWG	11/5/24	0517															
27	Water Product	P	DWG	10/18/24	0519															
28	Soil/Solid	SL	DWG		0519															
29	Oil	OL	DWG		0520															
30	Wipe	WP	DWG		0522															
31	Air	AR	DWG		0524															
32	Other	OT	DWG		0459															
33	Tissue	TS	DWG		0459															
34			DWG		0539															
35			DWG		0533															
36			DWG		0538															

ADDITIONAL COMMENTS		RELINQUISHED BY / AFFILIATION		DATE		TIME		ACCEPTED BY / AFFILIATION		DATE		TIME		SAMPLE CONDITIONS	
		Aleisha Hartford		11/8		1700		Aleisha Hartford		11/18		1200			
		Aleisha Hartford		11/14		1215		Aleisha Hartford		11/14		1215			
		Aleisha Hartford		11/14		1700		Aleisha Hartford		11/15		6:00			

Effective Date:

WO#: 70332847

Client Name: Oswego City CS

Project #

PM: MC1

Due Date: 01/24/25

Courier: Fed Ex UPS USPS Client Commercial Pac Other

CLIENT: OswegoCityCS

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No

Packing Material: Bubble Wrap Bubble Bags Ziplo Non Other Type of Ice: Wet Blue None

Thermometer Used: 74211 Correction Factor: 0 Samples on ice, cooling process has begun

Cooler Temperature (°C): 19.1 Cooler Temperature Corrected (°C): 19.1 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: AEB 1/15/25

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <u>WT</u> OIL OTHER	

Date and Initials of person checking preservation: AEB 1/15/25

All containers needing preservation have been pH paper Lot # <u>213624</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH>12 Cyanide)	Sample #
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	14. Positive for Res. Chlorine? Y N
KI starch test strips Lot # Residual chlorine strips Lot #	15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Lead Acetate Strips Lot #	17.
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.