

Sample Identification # and Location	Location Description	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	NYSDOH Action Level
WAR 004	Break Room BOTTLE FILLER	10/8/2024 09:38	1/21/2025 09:10	70332886001	Lead	<1.0	5
WAR 006	Break Room Sink	10/8/2024 09:40	1/21/2025 09:16	70332886002	Lead	6.4	5

NYSDOH Action Level for Lead In Schools of 5 ppb

Units
ug/L
ug/L



January 22, 2025

Pete Colucci
CiTi BOCES Oswego City School District
2 Buccaneer Blvd
Oswego, NY 13126

RE: Project: OSWEGO WAREHOUSE
Pace Project No.: 70332886

Dear Pete Colucci:

Enclosed are the analytical results for sample(s) received by the laboratory on January 15, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Jennifer Aracri for
Michelle Cohen
michelle.cohen@pacelabs.com
516-370-6000
Project Manager

Enclosures

cc: Ian Rowberry, CiTi BOCES Oswego City School District
CiTi BOCES Safety and, CiTi BOCES Oswego City School
District



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: WAR 004								
Lab ID: 70332886001								
Collected: 10/08/24 09:38								
Received: 01/15/25 06:00								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/21/25 09:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

Sample: WAR 006		Lab ID: 70332886002	Collected: 10/08/24 09:40	Received: 01/15/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	6.4	ug/L	1.0	1		01/21/25 09:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

QC Batch: 380818

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70332886001, 70332886002

METHOD BLANK: 1998745

Matrix: Water

Associated Lab Samples: 70332886001, 70332886002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/21/25 08:51	

LABORATORY CONTROL SAMPLE: 1998746

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	51.5	103	85-115	

MATRIX SPIKE SAMPLE: 1998749

Parameter	Units	70332886001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	65.2	130	70-130	

MATRIX SPIKE SAMPLE: 1998751

Parameter	Units	70332886002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.4	50	56.7	101	70-130	

SAMPLE DUPLICATE: 1998748

Parameter	Units	70332886001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1998750

Parameter	Units	70332886002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	6.4	6.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: OSWEGO WAREHOUSE

Pace Project No.: 70332886

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332886001	WAR 004	EPA 200.8	380818		
70332886002	WAR 006	EPA 200.8	380818		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

WO#: 70332886

Client Name: Oswego City CS Project # _____
 Courier: Fed Ex UPS USPS Client Commercial Pac Other _____
 Tracking #: _____

PM: MC1 Due Date: 01/24/25
 CLIENT: OswegoCityCS

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc Non Other Type of Ice: Wet Blue None

Thermometer Used: TAZ11 Correction Factor: 0 Samples on ice, cooling process has begun
 Cooler Temperature (°C): 19.1 Cooler Temperature Corrected (°C): 19.1 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: AEB 1/15/25

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u>	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <u>WT</u> OIL OTHER	

Date and Initials of person checking preservation: AEB 1/15/25

All containers needing preservation have been <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A pH paper Lot # <u>213624</u> All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A NAOH > 12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # _____ Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u> KI starch test strips Lot # _____ Residual chlorine strips Lot # _____	14. Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u> Lead Acetate Strips Lot # _____	15. Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u>	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u>	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u>	
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <u>N/A</u>	17.

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.